

## Product Certification Schedule

Schedule No:	017/003/181
Licensee:	PRYSMIAN CABLES & SYSTEMS LTD., CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU
Factory:	PRYSMIAN CABLES & SYSTEMS LTD., HARRIET STREET, TRECYNON, ABERDARE, SOUTH WALES, CF44 7EN
Specification:	BS 7211:1998 Incorporating Amendments Nos. 1 & 2 - Electric cables - Thermosetting insulated, non-armoured cables for voltages up to and including 450/750V, for electric power, lighting and internal wiring, and having low emission of smoke and corrosive gases when affected by fire.
Type of Cable:	Table 7 - Thermosetting insulated, single-core, flat twin and flat 3-core sheathed cables with circuit protective conductor, 300/500V
HAR Document:	Not applicable
HAR Specification:	Not applicable
Range of Approval:	1sqmm to 1.5sqmm nominal cross-sectional area of conductors inclusive. Single-core . 1sqmm to 16sqmm nominal cross-sectional area of conductors inclusive. Flat-twin. 1sqmm to 1.5sqmm nominal cross-sectional area of conductors inclusive. Flat 3-core. Sheath - LTS2. Insulation - GP8.
Origin Thread:	Not applicable
Origin Mark:	BRITCABLE (A) or PRYSMIAN (A)



Expiry Date: 11/08/2014

Signed for and on behalf of the British Approvals Service for Cables

 Date 07/07/2011

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004