



Product Service

CERTIFICATE

No. Z10 14 08 73401 013

Holder of Certificate: OMRON Europe B.V.Via Torino 13/15
10046 Poirino
ITALY**Factory(ies):** 73401**Certification Mark:****Product:** Safety components
Safety Relay Unit**Model(s):** G9SR-BC201-RC
G9SR-AD201-RC
G9SR-EX031-T90-RC**Parameters:**
Operating temperature: -10°C to + 55°C
Storage temperature: -25°C to + 70°C
Operating voltage: 24V DC ± 20%**Tested according to:**
2006/42/EC
EN ISO 13849-1:2008 (Cat4, PL e)
EN 61508-1:2010 (SIL3)
EN 61508-2:2010 (SIL3)
EN 61508-3:2010 (SIL3)
EN 61508-4:2010 (SIL3)
EN 62061/A1:2013 (SILCL3)
EN 61496-1/A1:2008 (Type4)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: OP85885T**Valid until:** 2019-09-11**Date,** 2014-09-12
(Günter Greil)

Page 1 of 1

