


Compact Manifold Regulator



Also available in inch sizes.

Reverse flow function is equipped as a standard.

Compact Manifold Regulator Common Supply Type Series ARM11A




3. Regulator Block Stations

Symbol	Stations
1	1 station
2	2 stations
3	3 stations
4	4 stations
5	5 stations
6	6 stations
7	7 stations
8	8 stations
9	9 stations
М	10 stations

4. IN/OUT Fitting Type (Refer to the figure below.)

Metric s Mounting position			IN s	side			(JUT	side	2		Inch size Mounting position	-		IN s	side					side	2
Fitting type	S	traig			Elbov	N		light				\ Fitting type	9	traig			Elbov	N			Elboy	
Symbol	ø6		ø10	ø6		ø10		ø6	ø4	ø6		Symbol										
07		00	010	00	00	010	04	00	04	00		57	01/4	00/10	00/0	01/4	00/10	00/0	03/32	01/4	10J/JZ	1/1
07	-						-					58	ě						•			
09	-							-				59	-						•	-		
10							-					<u> </u>							•			
11		-						-				61								-		
12												62			-				•			
12			•					•			ł	69			•					-		
20									-			70									•	
20				-					•			70				•						•
21					-				-			72									•	
22					•				•			72					-					•
23	-					-			-			73									•	
24						•						74						-				•
20	-								-			77									•	
27	-											78	-									•
20		•							•			78									•	
30		-							•	-	ł	80		-								•
30												81			-						-	
33			-								ł	83			-							-
33				-						\vdash		<u> </u>										
34												<u> </u>										
35	-									\vdash		86							-			
30										$\left - \right $		87										
37										$\left - \right $		<u>88</u>										
38 Note) Wher											l	00										

Note) When the handle and the OUT piping are located on the same side, the elbow fitting is directed to the rear side (DIN rai side). Use caution to ensure the connector is not disturbed, depending on piping direction, when choosing to attach a digital pressure switch.



GSMC

Compact Manifold Regulator Common Supply Type Series ARM11A

5. Accessories

	Pressure dis	splay Note 1, 2)	S	upply bloc	k type ^{Note}	3)	Supply blo	ock mountir	g position
Symbol	Without pressure display	With pressure display	Common supply block	Common	3-way valve	3-way valve common supply block	L side (Left)	R side (Right)	B side (Both)
-									
Α									
В	•				•		•		
С									
D									
Е									
F					•				
G									
Н			•						
J									
К		•							
L									
М		•					•		
Ν									
0		•	-					•	
P		•						•	
Q		•						•	
R		•	•			-			

Note 1) Pressure display means either a pressure guage or a digital pressure switch is attached. When choosing to attach a digital pressure switch as an attachment, be sure to enter the symbol, referring to table 8, "Digital Presure Switch Output Specifications". Otherwise, a pressure gauge will come with the regulator.
 Note 2) Pressure gauges are not available with a copper-free specification.
 Note 3) Pressure switches are not available with a copper-free specification.

6. Options

Symbol	None	0.35 MPa setting Note 1)	Non- relieving	Note 2) Oil-free
-	•			
1				
2				
3				•
4				
5				
6				•
7				•

Note 1) A pressure gauge with a full span of 0.4 MPa is attached. Note 2) The oil-free specification is grease-free in the fluid contact area.

7. Unit Representation

Symbol	Description
-	Display unit for product name plate and pressure gauge: MPa
Z Note 1, 2)	Display unit for product name plate and pressure gauge: PSI
ZA Note 1, 3)	Digital pressure switch: with unit switching (MPa is initially set.)


Note 1) This option is available for use outside Japan only. (The SI unit has to be used in Japan.) Additionally, the pressure switch offers dual unit presentation in MPa and PSI.

- Note 2) The digital pressure switch is equipped with unit switching and initially set to PSI.
- Note 3) This option is available with the digital pressure switch.

Symbol




8. Digital Presure Switch



Ρ

Note) When a digital pressure switch is attached, the "pressure display" in table 5 "Accessories" will be equipped. The electrical entry is positioned on the side opposite the handle.

PNP open collector





pressure guage

With digital pressure switch

Common supply block





L side 10

3-way valve common supply block



3-way valve common supply block + **Pressure switch** block L side



Specifications

Manifold (Regulator block, Co	ly block, 3-way valve common supply block)			
Regulator construction		Direct acting		
Working principal		Diaphragm regulator		
Relief mechanism	Standard	Relief type		
	Optional	Non-relieving type		
Backflow function Note 1)		Within (Unbalance type)		
IN side tubing O.D.		ø6, ø8, ø10, ø1/4, ø5/16, ø3/8		
OUT side tubing O.D.		ø4, ø6, ø5/32, ø1/4		
Proof pressure		1.5 MPa		
Maximum operating pressure	1	1.0 MPa		
0-4	Standard	0.05 to 0.7 MPa		
Set pressure range	Optional	0.05 to 0.35 MPa (Low pressure type)		
Fluid		Air		
Ambient and operating fluid tem	perature Note 2)	5 to 60°C		


Note 1) 0.1 MPa or greater set pressure is required when used in the reverse flow. Note 2) 5 to 50°C when the digital pressure switch is used.

Refer to page 19, 21 for the digital pressure switch and pressure switch specifications.


Series ARM11A

Flow Characteristics


ARM11AA1-307 (One-touch fittings: IN ø6, OUT ø4) Condition: Inlet pressure 0.7 MPa




ARM11AA1-310 (One-touch fittings: IN ø8, OUT ø6) Condition: Inlet pressure 0.7 MPa









Pressure Characteristics




SMC















Compact Manifold Regulator Common Supply Type Series ARM11A

Construction



Component Parts

	•	
No.	Description	Material
1	Body for regulator block	PBT
2	Bonnet	PBT
3	Handle	POM
4	Valve seat	POM
5	Adjusting screw assembly	Reinforced steel
6	Adjustment spring	Steel wire
7	Regulator clip	Stainless steel
8	Manifold block	PBT
9	Blanking plate assembly	—
10	Square nut	Steel
11	Common exhaust bushing	POM

Replacement Parts

No.	Description	Material	Part no.	Note
A	Diaphragm	Weatherproof	136126A	Relieving type
A	assembly	NBR, POM	136126-1A	Non-relieving type
В	Valve	HNBR, Aluminum alloy	136127-30#1	
С	Valve spring	Stainless steel	136131	
D	Gasket	HNBR	136137-30	
Е	O-ring	NBR	136146	Standard model
E	0-mig	HNBR	136146-30	Oil-free specification
F	O-ring	NBR	136147	Standard model
	0-mig	HNBR	136147-30	Oil-free specification
		NBR	136148	Standard model
G	O-ring	HNBR	136148-30	Oil-free specification
a	0-mig	NBR	KA01731	Standard model for digital pressure switch
		HNBR	KA01613	Oil-free spec. for digital pressure switch
н	O-ring	NBR	136149	Standard model
-	0-mig	HNBR	136149-30	Oil-free specification
J	Fitting assembly	_	Refer to page 22.	
K	Port plug	PBT/HNBR	Refer to page 23.	



Series ARM11A


Dimensions


ARM11AA1-□12

Handle position: Top / Common supply block

Stations	DIN rail part no. (for L and R sides)	L2 dimension
1	AXT100-DR-9	123
2	AXT100-DR-11	148
3	AXT100-DR-13	173
4	AXT100-DR-16	210.5
5	AXT100-DR-18	235.5
6	AXT100-DR-20	260.5
7	AXT100-DR-22	285.5
8	AXT100-DR-25	323
9	AXT100-DR-27	348
М	AXT100-DR-29	373

For One-touch fitting parts and manifold option dimensions, refer to page 16 through to 23.






ARM11AA1-□12-A Handle position: Top / Common supply block with pressure switch


84

Ð

آ ال

Stations	DIN rail part no. (for L and R sides)	L2 dimension
1	AXT100-DR-9	123
2	AXT100-DR-11	148
3	AXT100-DR-13	173
4	AXT100-DR-16	210.5
5	AXT100-DR-18	235.5
6	AXT100-DR-20	260.5
7	AXT100-DR-22	285.5
8	AXT100-DR-25	323
9	AXT100-DR-27	348
М	AXT100-DR-29	373






28

SMC

S

39

52.5




Dimensions


ARM11AA1-□12-B


Handle position: Top / 3-way valve common supply block

For One-touch fitting parts and manifold option dimensions, refer to page 16 through to 23.

Stations	DIN rail part no. (for L and R sides)	L2 dimension
1	AXT100-DR-9	123
2	AXT100-DR-11	148
3	AXT100-DR-13	173
4	AXT100-DR-16	210.5
5	AXT100-DR-18	235.5
6	AXT100-DR-20	260.5
7	AXT100-DR-22	285.5
8	AXT100-DR-25	323
9	AXT100-DR-27	348
М	AXT100-DR-29	373









ARM11AA1-□12-C Handle position: Top / 3-way valve common supply block + Pressure switch block

Stations	DIN rail part no.	L2 dimension
1	AXT100-DR-11	148
2	AXT100-DR-13	173
3	AXT100-DR-15	198
4	AXT100-DR-17	223
5	AXT100-DR-19	248
6	AXT100-DR-22	285.5
7	AXT100-DR-24	310.5
8	AXT100-DR-26	335.5
9	AXT100-DR-28	360.5
М	AXT100-DR-31	398





Series ARM11A


Dimensions


ARM11AB1-□12

Handle position: Front / Common supply block

Stations	DIN rail part no.	L2 dimension
1	AXT100-DR-9	123
2	AXT100-DR-11	148
3	AXT100-DR-13	173
4	AXT100-DR-16	210.5
5	AXT100-DR-18	235.5
6	AXT100-DR-20	260.5
7	AXT100-DR-22	285.5
8	AXT100-DR-25	323
9	AXT100-DR-27	348
М	AXT100-DR-29	373


For One-touch fitting parts and manifold option dimensions, refer to page 16 through to 23.







ARM11AB1-□12-A Handle position: Front / Common supply block with pressure switch

Stations	DIN rail part no.	L2 dimension
1	AXT100-DR-9	123
2	AXT100-DR-11	148
3	AXT100-DR-13	173
4	AXT100-DR-16	210.5
5	AXT100-DR-18	235.5
6	AXT100-DR-20	260.5
7	AXT100-DR-22	285.5
8	AXT100-DR-25	323
9	AXT100-DR-27	348
М	AXT100-DR-29	373








Dimensions


ARM11AB1-D12-B


Handle position: Front / 3-way valve common supply block

For One-touch fitting parts and manifold option dimensions, refer to page 16 through to 23.

Stations	DIN rail part no. L2 dimension	
1	AXT100-DR-9	123
2	AXT100-DR-11	148
3	AXT100-DR-13	173
4	AXT100-DR-16	210.5
5	AXT100-DR-18	235.5
6	AXT100-DR-20	260.5
7	AXT100-DR-22	285.5
8	AXT100-DR-25	323
9	AXT100-DR-27	348
М	AXT100-DR-29	373








ARM11AB1-□12-C Handle position: Front / 3-way valve common supply block + Pressure switch block


Stations	DIN rail part no.	L2 dimension			
1	AXT100-DR-11	148			
2	AXT100-DR-13 173				
3	AXT100-DR-15 198				
4	AXT100-DR-17	223			
5	AXT100-DR-19 248				
6	AXT100-DR-22	285.5			
7	AXT100-DR-24	310.5			
8	AXT100-DR-26	335.5			
9	AXT100-DR-28	360.5			
М	AXT100-DR-31	398			



L2

28

SNO



നി

ß

Series ARM11A


Dimensions


ARM11AC2-D12

Handle position: Bottom / Common supply block

Stations	DIN rail part no.	L2 dimension
1	AXT100-DR-9	123
2	AXT100-DR-11	148
3	AXT100-DR-13	173
4	AXT100-DR-16	210.5
5	AXT100-DR-18	235.5
6	AXT100-DR-20	260.5
7	AXT100-DR-22	285.5
8	AXT100-DR-25	323
9	AXT100-DR-27	348
М	AXT100-DR-29	373


For One-touch fitting parts and manifold option dimensions, refer to page 16 through to 23.







ARM11AC2-□12-A Handle position: Bottom / Common supply block with pressure switch

Stations	DIN rail part no.	L2 dimension
1	AXT100-DR-9	123
2	AXT100-DR-11	148
3	AXT100-DR-13	173
4	AXT100-DR-16	210.5
5	AXT100-DR-18	235.5
6	AXT100-DR-20	260.5
7	AXT100-DR-22	285.5
8	AXT100-DR-25	323
9	AXT100-DR-27	348
М	AXT100-DR-29	373







SMC

Dimensions

ARM11AC2-D12-B


Handle position: Bottom / 3-way valve common supply block


84

56

For One-touch fitting parts and manifold option dimensions, refer to page 16 through to 23.


Stations	DIN rail part no. L2 dimension	
1	AXT100-DR-9	123
2	AXT100-DR-11	148
3	AXT100-DR-13	173
4	AXT100-DR-16	210.5
5	AXT100-DR-18	235.5
6	AXT100-DR-20	260.5
7	AXT100-DR-22	285.5
8	AXT100-DR-25	323
9	AXT100-DR-27	348
М	AXT100-DR-29	373







ARM11AC2-□12-C Handle position: Bottom / 3-way valve common supply block + Pressure switch block

Stations	DIN rail part no.	L2 dimension
1	AXT100-DR-11	148
2	AXT100-DR-13	173
3	AXT100-DR-15 198	
4	AXT100-DR-17	223
5	AXT100-DR-19	248
6	AXT100-DR-22	285.5
7	AXT100-DR-24	310.5
8	AXT100-DR-26	335.5
9	AXT100-DR-28	360.5
М	AXT100-DR-31	398









Compact Manifold Regulator Individual Supply Type Series ARM11B


How to Order



4. IN/OUT Fitting Type (Refer to the figure below.)



Note) When the handle and the OUT piping are located on the same side, the elbow fitting is directed to the rear side (DIN rail side). Use caution to ensure the connector is not disturbed, depending on piping direction, when choosing to attach a digital pressure switch.



3. Regulator Block Stations

Symbol	Stations
1	1 station
2	2 stations
3	3 stations
4	4 stations
5 5 stations	
6 6 stations	
7 7 stations	
8 8 stations	
9	9 stations
М	10 stations

11

OUT piping position: Bottom

Compact Manifold Regulator Individual Supply Type Series ARM11B

5. Accessory (Pressure Display)

J. ALLES	soly (Plessule Display	0			<u>6. Optic</u>	ns		
Symbol -	Accessory Without pressure display	Without pressure display		With ure display	Symbol	None	0.35 MPa setting Note 1)	Non- relieving
A Note 1, 2)	With pressure display	L.B.		(Bernell)	-			
Note 1) Pre	ssure display means a pressure	6	N04 062		1			
	ge or a digital pressure switch	SMC	-0.2	GIMC PRESSURE	2			
	ttached.		0 MPa		3			
	en choosing to attach a ital pressure switch as an	(3)	SMC	OUT MPa	4			•
•	ichment, be sure to enter the				5			
syn	nbol, referring to table 8,	SVC	Cal	(Standard)	6			•
	gital Presure Switch Output				7			•
pre	ecifications". Otherwise, a ssure gauge will come with regulator.				at	ached.	auge with a f	•
,	ssure gauges are not available a copper-free specification.		With pressure guage	With digital pressure switch	,	e oil-free s ntact area.	pecification is	s grease-free

7. Unit Representation

Symbol	Description
-	Display unit for product name plate and pressure gauge: MPa
Z Note 1, 2)	Display unit for product name plate and pressure gauge: PSI
ZA Note 1, 3)	Digital pressure switch: with unit switching (MPa is initially set.)

Note 1) This option is available for use outside Japan only. (The SI unit has to be used in Japan.)

Note 2) The digital pressure switch is equipped with unit switching and initially set to PSI.

Note 3) This option is available with the digital pressure switch.

6 Ontions

Symbol	None	0.35 MPa setting Note 1)	Non- relieving	Note 2 Oil-free
-				
1				
2				
3				•
4				
5				•
6				•
7				•

0.4 MPa is ee in the fluid

8. Digital Presure Switch Output Specifications Note)

Symbol	Details
-	None
Ν	NPN open collector
Р	PNP open collector

Note) When a digital pressure switch is attached, the "pressure display" in table 5 "Accessory" will be equipped. The electrical entry is positioned on the side opposite the handle.

Specifications

Regulator construction		Direct acting	
Working principal		Diaphragm regulator	
Relief mechanism	Standard	Relief type	
Relief mechanism	Optional	Non-relieving type	
Backflow function Note 1)		Within (Unbalance type)	
IN side tubing O.D.		ø4, ø6, ø5/32, ø1/4	
OUT side tubing O.D.		ø4, ø6, ø5/32, ø1/4	
Proof pressure		1.5 MPa	
Maximum operating pressure		1.0 MPa	
0-1	Standard	0.05 to 0.7 MPa	
Set pressure range	Optional	0.05 to 0.35 MPa (Low pressure type)	
Fluid		Air	
Ambient and operating fluid temperature Note 2)		5 to 60°C	

Note 1) 0.1 MPa or greater set pressure is required when used in the reverse flow. Note 2) 5 to 50°C when the digital pressure switch is used.


Refer to page 19 for the digital pressure switch specifications.





Series ARM11B

Construction




Component Parts

N	Description	Material
1	Body for regulator block	PBT
2	Bonnet	PBT
3	Handle	POM
4	Valve seat	POM
5	Adjusting screw assembly	Reinforced steel
6	Adjustment spring	Steel wire
_7	Regulator clip	Stainless steel
8	Manifold block	PBT
g	Blanking plate assembly	_
1) Square nut	Steel
1	I Individual supply bushing	POM


Replacement Parts

No.	Description	Material	Part no.	Note			
Α	Diaphragm	Weatherproof	136126A	Relieving type			
A	assembly	NBR, POM	136126-1A	Non-relieving type			
в	Valve	HNBR, Aluminum alloy	136127-30#1				
С	Valve spring	Stainless steel	136131				
D	Gasket	HNBR	136137-30				
Е	O-ring	NBR	136146	Standard model			
E	0-ring	HNBR	136146-30	Oil-free specification			
F	O-ring	NBR	136147	Standard model			
Г		HNBR	136147-30	Oil-free specification			
		NBR	136148	Standard model			
G	O-ring	HNBR	136148-30	Oil-free specification			
a	0-mig	NBR	KA01731	Standard model for digital pressure switch			
		HNBR	KA01613	Oil-free spec. for digital pressure switch			
н	O ring	NBR	136149	Standard model			
"	O-ring	HNBR	136149-30	Oil-free specification			
J	Fitting assembly	—	Refer to page 22.				
К	Port plug	PBT/HNBR	Refer to page 23.				


Flow Characteristics




ARM11BA1-307 (One-touch fittings: IN ø6, OUT ø4) Condition: Inlet pressure 0.7 MPa





ARM11BA1-308 (One-touch fittings: IN/OUT ø6) Condition: Inlet pressure 0.7 MPa





Pressure Characteristics



















SMC

Series **ARM11B**


Dimensions


ARM11BA1-□08 Handle position: Top







ARM11BB1-□08 Handle position: Front











AXT100-DR-28

ARM11BC2-□08 Handle position: Bottom





Stations	DIN rail part no.	L2 dimension
1	AXT100-DR-8	110.5
2	AXT100-DR-10	135.5
3	AXT100-DR-12	160.5
4	AXT100-DR-14	185.5
5	AXT100-DR-16	210.5
6	AXT100-DR-19	248
7	AXT100-DR-21	273
8	AXT100-DR-23	298
9	AXT100-DR-25	323
М	AXT100-DR-28	360.5

1	AXT100-DR-8	110.5
2	AXT100-DR-10	135.5
3	AXT100-DR-12	160.5
4	AXT100-DR-14	185.5
5	AXT100-DR-16	210.5
6	AXT100-DR-19	248
7	AXT100-DR-21	273
8	AXT100-DR-23	298
9	AXT100-DR-25	323
М	AXT100-DR-28	360.5

DIN rail part no.

L2 dimension

323

360.5


Stations

9


М

Compact Manifold Regulator **Options**

Common Supply Type



Individual Supply Type



Series ARM11A/B

Regulator Block


Common Supply Type ARM11A A 1 04 R 3

1. Handle Position


Α


В

С



16 17





2. OUT Piping Position

3

Symbol	Position
1	Bottom
2	Тор

3.001	Fitting	Гуре			
Metric s	size				Inc
Fitting type	Stra	aight	Elb	ow	\ Fitti
Symbol	ø4	ø6	ø4	ø6	Sy
04					ļ
05					

Inch size						
Elbow		Fitting type		Straight		WO
ø4	ø6	Symbol	ø5/32	ø1/4	ø5/32	ø1/4
		54				
		55				
•		66				
		67				


4. Accessory (Pressure Display)

Symbol	Accessory
-	Without pressure display
A Note 1, 2)	With pressure display

Note 1) Pressure display means either a pressure gauge or a digital pressure switch is attached. When choosing to attach a digital pressure switch as an attachment, be sure to enter the symbol, referring to table 7, "Digital Presure Switch Output Specifications". Otherwise, a pressure gauge will come with the regulator.

Note 2) Pressure gauges are not available with a copperfree specification.

5. Options



Note 2) The oil-free specification is grease-free in the fluid contact area.

6. Unit Representation

Symbol	Description
-	Display unit for product name plate and pressure gauge: MPa
Z Note 1, 2)	Display unit for product name plate and pressure gauge: PSI
ZA Note 1, 3)	Digital pressure switch: with unit switching (MPa is initially set.)

Note 1) This option is available for use outside Japan only. (The SI unit has to be used in Japan.) Additionally, the pressure switch offers dual unit presentation in MPa and PSI.

Note 2) The digital pressure switch is equipped with unit switching and initially set to PSI

Note 3) This option is available with the digital pressure switch.

7. Digital Presure Switch Output Specifications Note)

Symbol	Details	
-	None	
N	NPN open collector	
Р	PNP open collector	
Note) When a digital pressure switc		

attached, the "pressure display" in table 4 "Accessory" will be equipped. The electrical entry is positioned on the side

opposite the handle.




Compact Manifold Regulator Series ARM11A/B

Regulator Block

Individual Supply Type ARM11B A 1 - R 06 - A Z N


1. Handle Position






Handle position Top

84





2. IN/OUT Piping Position

3. IN/OUT Fitting Type



Metric size






4. Accessory (Pressure Display)

Symbol	Accessory
-	Without pressure display
A Note 1, 2)	With pressure display

Note 1) Pressure display means either a pressure gauge or a digital pressure switch is attached. When choosing to attach a digital pressure switch as an attachment, be sure to enter the symbol, referring to table 7, "Digital Presure Switch Output Specifications". Otherwise, a pressure gauge will come with the regulator.

Note 2) Pressure gauges are not available with a copperfree specification.

5. Options



Note 1) A pressure gauge with a full span of 0.4 MPa is attached. Note 2) The oil-free specification is grease-free in the fluid contact area.

6. Unit Representation

Symbol	Description
-	Display unit for product name plate and pressure gauge: MPa
Z Note 1, 2)	Display unit for product name plate and pressure gauge: PSI
ZA Note 1, 3)	Digital pressure switch: with unit switching (MPa is initially set.)

Note 1) This option is available for use outside Japan only. (The SI unit has to be used in Japan.) Additionally, the pressure switch offers dual unit presentation in MPa and PSI.

Note 2) The digital pressure switch is equipped with unit switching and initially set to PSI.

Note 3) This option is available with the digital pressure switch.

7. Digital Presure Switch Output Specifications Note)

Symbol	Details		
-	None		
Ν	NPN open collector		
Р	PNP open collector		

Note) When a digital pressure switch is

attached, the "pressure display" in table 4 "Accessory" will be equipped. The electrical entry is positioned on the side opposite the handle.

Series ARM11A/B


Digital Pressure Switch

Specificati	ons						
Rated pressure range			0 to 1 MPa				
Set pressur	e range		-0.1 to 1 MPa				
Withstand p	oressure		1.5 MPa				
Set pressur	e resolution		0.01 MPa				
Power supp	ly voltage		12 to 24 VDC, Ripple (p-p) 10% or less (With power supply polarity protection)				
Current con	sumption		55 mA or less (at no load)				
Switch outp	out		NPN or PNP open collector output: 1 output				
	Max. load c	urrent	80 mA				
	Max. applie	d voltage	30 V (With NPN output)				
	Residual voltage Response time Anti-chattering function		1 V or less (With load current of 80 mA)				
			1 s (0.25, 0.5, 2, 3 selections)				
	Short circui	t protection	Yes				
Repeatabilit	ty		±1% F.S. or less				
Hysteresis	Hysteresis	mode	Adjustable (see he set from 0)				
	Window com	parator mode	Adjustable (can be set from 0)				
Display			3-digit, 7-segment indicator, 2-color display (Red /Green) A switch can be operated simultaneously.				
Display accuracy			±2% F.S. ± 1 digit (at 25°C ± 3°C ambient temperature)				
Indicator lig	lht		Illuminates when output is ON. (Green)				
Environment	al resistance	Enclosure	IP40				
Lead wire w	vith connecto	or	ø3.4 3-wire 25 AWG 2 m				

Output specification


NPN open collector

Max. 30 V, 80 mA Residual voltage 1 V or less




PNP open collector

Max. 80 mA Residual voltage 1 V or less



□28


10.5



Refer to Instruction Manual for settings, how-to-operate, etc.

SMC

Common Supply Block



1. IN Piping Position

Symbol	Position
1	Bottom
2	Тор

3. IN Fitting Type

		<u> </u>												
Metri	ic si	ze					l	Inch	size	;				
Fitting type	S	traig	ht	t Elbow			Fitting type	Straight		Elbow		/		
Symbol	Ø6	Ø8	ø10	Ø6	Ø8	ø10		Symbol	Ø1/4	Ø5/16	Ø3/8	Ø1/4	Ø5/16	Ø3/8
01								51	•					
02								52						
03								53						
13								63						
14								64						
15								65						

4. Option

Symbol	Description
-	None
3	Oil-free

Note) The oil-free type has non-greased fluid contact areas.

5. Accessory

Symbol	Description
-	Pressure switch lead wire length: 0.5 m
Α	Pressure switch lead wire length: 3.0 m

Note) Leave the field blank for types without pressure switch.

6. Unit Representation

Symbol	Description
-	Display unit for product name plate: MPa
Z Note)	Display unit for product name plate: PSI

Note) This option is available for use outside Japan only. (The SI unit has to be used in Japan.) Additionally, the pressure switch offers dual unit presentation in MPa and PSI.


2. Common Supply Block Type


Symbol	Description
S	Common supply block
Р	Common supply block with pressure switch
V	3-way valve common supply block
W	3-way valve common supply block + Pressure switch block

Note) The oil-free specification is not available for P and W types of common supply blocks (types with pressure switch).

Common supply block (S)

Common supply block with pressure switch (P)






3-way valve


block (V)

56 56 20 4


3-way valve common supply block common supply

Pressure switch block (W)





20



Series ARM11A/B

Pressure Switch Block




1. Accessory

Symbol	Description
-	Pressure switch lead wire length: 0.5 m
Α	Pressure switch lead wire length: 3.0 m

2. Unit Representation

Symbol	Description
-	Display unit for product name plate: MPa
Z Note)	Display unit for product name plate: PSI

Note) This option is available for use outside Japan only. (The SI unit has to be used in Japan.) Additionally, the pressure switch offers dual unit presentation in MPa and PSI.




Set Pressure Range


Specifications

Pressure switch (Common supply block with pressure switch, 3-way valve common supply block plus pressure switch block)

Contact type	Reed type				
Contact construction	Reed switch type				
Contact component		1a			
Reed switch action	Pisto	on type (built-in mag	gnet)		
Wiring specification		Grommet type			
Wiring length	0.	5 m (standard mode	el)		
Proof pressure	1.0 MPa				
Maximum operating pressure	0.7 MPa				
Set pressure range	0.1 to 0.6 MPa				
Hysteresis	0.08 MPa or less				
Repeatability		±0.05 MPa			
Maximum contact capacity		AC 2 VA, DC 2 W			
Operating voltage AC, DC	24 V or less	48 V	100 V		
Max. operating current and range	50 mA 40 mA 20 mA				
Impact resistance	30 G				
Environmental resistance Enclosure	IP40				



Electric Circuit




DIN Rail

• When only DIN rail is required:

DIN rail part no.


AXT100-DR-n Note) Put an appropriate No. from the table below in the place of "n." For the L dimension, please refer to "Dimensions."



L Dimension

L Dimensio	n								L	_=12.5 x n+10.5
NO.	1	2	3	4	5	6	7	8	9	10
L	23	35.5	48	60.5	73	85.5	98	110.5	123	135.5
			_				_	_		
NO.	11	12	13	14	15	16	17	18	19	20
L	148	160.5	173	185.5	198	210.5	223	235.5	248	260.5
NO.	21	22	23	24	25	26	27	28	29	30
L	273	285.5	298	310.5	323	335.5	348	360.5	373	385.5
NO.	31	32	33	34	35	36	37	38	39	40
L	398	410.5	423	435.5	448	460.5	473	485.5	498	510.5

One-touch Fittings for Regulator Block



Fitting size

ø4, ø5/32

ø6

ø1/4

Х

11.5

11.5

11.5


Υ


19

22


19.5

One-touch Fittings for Common Supply Block





Fitting size	X
ø6	5
ø8, ø5/16	5
ø10, ø3/8	5.5
ø1/4	5




Fitting size	Х	Y
ø6	19	20
ø8, ø5/16	20	23
ø10, ø3/8	22	26
ø1/4	19	20.5

Fitting size	X
ø4, ø5/32	3
ø6	3
ø1/4	7





Series ARM11A/B

End Block



L side end block





SMC

20

32.5


26


Pressure Gauge

Part no.	Pressure gauge indication range	Indication unit
GC3-4A-X2101	0 to 0.4 MPa	MPa
GC3-10A-X2101	0 to 1.0 MPa	IVIFa
GC3-P4A-X2101	0 to 60 PSI	PSI
GC3-P10A-X2101	0 to 150 PSI	F31


Specifications

Display accuracy	±3%F.S. (Full Span)
Calibration angle	230°
Limit indicator	With limit indicator






Port Plug





Bushing

Part no.	Description
136144-S	Common supply bushing
136144-K	Individual supply bushing










Regulator Single Unit Type Series ARM10

How to Order



1. IN/OUT Fitting Type

Metric	size)							Inch s	ize				
Mounting position		IN s	side			OUT	side		Mounting position		IN s	side		Γ
\Fitting type	Stra	ight	Elbov	N Note)	Stra	light	Elboy	N Note)	Fitting type	Stra	light	Elbov	N Note)	Ī
Symbol	ø4	ø6	ø4	ø6	ø4	ø6	ø4	ø6	Symbol	ø5/32	ø1/4	ø5/32	ø1/4	Ι
06									56					Ī
07		•							57					Ī
08		•							58					Ī
18									68					Ī
19									69					Ī
20									70					Ī
25									75					Ī
26		•							76					Ī
27		•							77					Ī
32									82					Ī
33									83					T
34									84					I

Note) Use caution to ensure the connector is not disturbed, depending on piping direction, when choosing to attach a digital pressure switch.

2. Accessories

Symbol	None	Note 1) Bracket	Note 2) Pressure gauge	Panel nut
-	•			
В		•		(●)
G				
Р				•
BG GP				(●)
GP			•	•

Note 1) In case of a type with bracket, the panel nut is included.

Note 2) Pressure display means either a pressure gauge or a digital pressure switch is attached When choosing to attach a digital pressure switch as an attachment, be sure to enter the symbol, referring to table 5, "Digital Presure Switch Output Specifications". Otherwise, a pressure gauge will come with the regulator. Additionally, the pressure gauge cannot be changed to a copper-free model.

3. Options

Symbol	None	0.35 MPa setting Note 1)	Non- relieving	Note 2) Oil-free
Nil				
1				
2			•	
3				•
4			•	
5				•
6			•	•
7			•	•

Note 1) A pressure gauge with a full span of 0.4 MPa is attached. Note 2) The oil-free specification is grease-free in the fluid contact area.

5. Digital Presure Switch Output Specifications Note)

Symbol	Details		
-	None		
Ν	NPN open collector		
Р	PNP open collector		

Note) When a digital pressure switch is attached, the "pressure display" in table 2 "Accessories" will be equipped. The electrical entry is positioned on the side opposite the handle.

4. Unit Representation

Bracket

	Symbol	Description
 Display unit for product name plate and pressure gauge: M 		
	Z Note 1, 2) Display unit for product name plate and pressure gauge: P	
	ZA Note 1, 3)	Digital pressure switch: with unit switching (MPa is initially set.)

OUT side

ø5/32 ø1/4 ø5/32 ø1/4

•

-

•

Elbow Note)

Straight

•

Panel nut

Pressure


gauge

Note 1) This option is available for use outside Japan only. (The SI unit has to be used in Japan.) Additionally, the pressure switch offers dual unit presentation in MPa and PSI

Note 2) The digital pressure switch is equipped with unit switching and initially set to PSI.

Note 3) This option is available with the digital pressure switch.

SMC






Digital pressure switch

Series ARM10

Front Handle Type **ARM10F** 06 В (†) (2)3 4 IN side 1. IN/OUT Piping Position Тор Тор OUT side \Position IN side OUT side Example of panel Bottom Top Symbol Bottom Тор mounting 1 2 • 3 • • 4 IN side OUT side Bottom Bottom

How to Order

2. IN/OUT Fitting Type



Note) Use caution to ensure the connector is not disturbed, depending on piping direction, when choosing to attach a digital pressure switch.

3. Accessories


Symbol	None	Note 1) Bracket	Pressure display	Panel nut	Note 3) Decorative cover
-	•				
В				(•)	
G					
BG				(●)	
GP				•	
GPC Note 4)				•	

Note 1) In case of a type with bracket, the panel nut is included. Note 2) Pressure display means either a pressure gauge or a

digital pressure switch is attached. When choosing to attach a digital pressure switch as an attachment, be sure to enter the symbol, referring to table 6, "Digital Presure Switch Output Specifications". Otherwise, a pressure gauge will come with the regulator. Additionally, the pressure gauge cannot be changed to a copper-free model.

Note 3) Not attachable to a model with digital pressure switch.

Note 4) Please note that the dimensions will be bigger when GPC is selected.



Regulator Single Unit Type Series ARM10

4. Options

Symbol	None	0.35 MPa setting Note 1)	Non- relieving	Note 2) Oil-free
-				
1				
2				
3				•
4				
5				•
6				•
7				

5. Unit Representation

Symbol	Description				
-	Display unit for product name plate and pressure gauge: MPa				
Z ^{Note 1, 2)} Display unit for product name plate and pressure gauge:					
ZA Note 1, 3) Digital pressure switch: with unit switching (MPa is initially set.					
Note 1) This option is available for use outside Japan only. (The SI unit has to be used in Japan.)					
Note 2) The digital pressure switch is equipped with unit switching and initially set to PSI					

Note 3) This option is available with the digital pressure switch.

Note 1) A pressure gauge with a full span of 0.4 MPa is attached. Note 2) The oil-free specification is grease-free in the fluid contact area.

6. Digital Presure Switch Output Specifications Note)

Symbol	Details	
-	None	
N	NPN open collector	
Р	PNP open collector	

Note) When a digital pressure switch is attached, the "pressure display" in table 3 "Accessories" will

be equipped.

The electrical entry is positioned on the side opposite the handle.

Specifications

Model		ARM10	ARM10F
Regulator construction	Direct acting		
Working principal	Diaphragm regulator		
Standard		Relief type	
Relief mechanism	Optional	Non-relieving type	
Backflow function Note 1)		Within (unbalance type)	
IN side tubing O.D.	ø4, ø6, ø5/32, ø1/4		
OUT side tubing O.D.	ø4, ø6, ø5/32, ø1/4		
Proof pressure	1.5 MPa		
Maximum operating pressure	1.0 MPa		
Set pressure range Standard Optional		0.05 to 0.7 MPa	
		0.05 to 0.35 MPa (Low pressure type)	
Fluid	Air		
Ambient and operating fluid temperation	5 to 60°C		
Weight	60 g	72 g	

Note 1) 0.1 MPa or greater set pressure is required when used in the reverse flow. Note 2) 5 to 50°C when the digital pressure switch will be used.

Refer to page 19 for the digital pressure switch specifications.

Symbol



Relieving type




Non-relieving type


Series ARM10

Flow Characteristics












ARM10F-08




Pressure Characteristics






ARM10F -07-1






ARM10F
-08-1


SMC






Regulator Single Unit Type Series ARM10

Construction





Component Parts


No.	Description	Material
1	Body	PBT
2	Bonnet	PBT
3	Handle	POM
4	Valve seat	POM
5	Adjusting screw assembly	Reinforced steel
6	Adjustment spring	Steel wire
7	Regulator clip	Stainless steel
8	Blanking plate assembly	_
9	Square nut	Steel

Replacement Parts

No.	Description	Material	Part no.	Note
Α	Diaphragm	Weatherproof	136126A	Relieving type
A	assembly	NBR, POM	136126-1A	Non-relieving type
В	Valve	HNBR, Aluminum alloy	136127-30#1	
С	Valve spring	Stainless steel	136131	
D	O-ring	NBR	136146	Standard model
		HNBR	136146-30	Oil-free specification
Е	O-ring	NBR	136147	Standard model
E		HNBR	136147-30	Oil-free specification
	O-ring	NBR	136148	Standard model
F		HNBR	136148-30	Oil-free specification
Г		NBR	KA01731	Standard model for digital pressure switch
		HNBR	KA01613	Oil-free spec. for digital pressure switch
G	Fitting assembly	_	Refer to page 30.	
G	Fitting assembly			

Dimensions

ARM10-06





For dimensions of accessories and One-touch fitting parts, please refer to page 30

Series ARM10

Dimensions








Pressure Gauge

Part no.	Pressure gauge indication range	Indication unit	
		indication unit	
GC3-4A-X2101	0 to 0.4 MPa	MPa	
GC3-10A-X2101	0 to 1.0 MPa		
GC3-P4A-X2101	0 to 60 PSI	PSI	
GC3-P10A-X2101	0 to 150 PSI	1.51	

Specifications


Display accuracy	±3% F.S. (Full Span)	
Calibration angle	230°	
Limit indicator	With limit indicator	
Weight	17 g	




Digital Pressure Switch

Refer to page 19.


Panel Nut






Decorative Cover

Part no.	136155
Material	PBT
Weight	0.5 g



One-touch Fittings for Regulator



Series **ARM10F** Made to Order

Please contact SMC regarding detailed specifications, dimensions and delivery.

Regulator Single Unit Front Handle Type/ For Manifold

Specifications

Regulator construction		Direct acting	
Working principal		Diaphragm regulator	
Relief mechanism	Standard	Relief type	
Relief mechanism	Optional	Non-relieving type	
Backflow function Note2)		Within (Unbalance type)	
IN/OUT air passage diameter		ø4	
IN/OUT gasket sealing O.D.		ø7	
Proof pressure		1.5 MPa	
Maximum operating pressure		1.0 MPa	
Set pressure range Standard		0.05 to 0.7 MPa	
Set pressure range	Optional	0.05 to 0.35 MPa (Low pressure type)	
Fluid		Air	
Ambient and fluid temperature Note)		5 to 60°C	
Weight		73 g	

Note 1) Two mounting bolts and two O-rings are attached.

Note 2) 0.1 MPa or greater set pressure is required when used in the reverse flow.

Note 3) 5 to 50°C when the digital pressure switch will be used. Refer to page 19 for the digital pressure switch specifications.

How to Order

ARM10F -X201

1. Accessory (Pressure Display)

Enter symbol for when the model requires a digital pressure switch.

Symbol	Accessory	
- Without pressure display		
A With pressure display		

Note 1) Pressure display means either a pressure gauge or digital pressure switch is attached. When choosing to attach a digital pressure switch as an attachment, be sure to enter the symbol, referring to table 4, "Digital Presure Switch Output Specifications". Otherwise, a pressure gauge will come with the regulator.

Note 2) Pressure gauges are not available with a copper-free specification.

2. Options

Symbol	None	0.35 MPa setting Note 1)	Non-relieving	Oil-free Note 2)
-	•			
1				
2			•	
3				•
4		•	•	
5				•
6			•	•
7				•

Note 1) A pressure gauge with a full span of 0.4 MPa is attached. Note 2) The oil-free type has non-greased fluid contact areas.


Dimensions

For manifold

Symbol	Description
-	Display unit for product name plate and pressure gauge: MPa
Z Note 1, 2)	Display unit for product name plate and pressure gauge: PSI
ZA Note 1, 3)	Digital pressure switch: with unit switching (MPa is initially set.)

o PSI.

Example




manifold base

Output Specifications Note)

Symbol	Details	
-	None	
Ν	NPN open collector	
Р	PNP open collector	

Note) When a digital pressure switch is attached, the "pressure display" in table 1 "Accessory" will be equipped. The electrical entry is positioned on the side opposite the handle.



3. Unit Representation

		Display unit for product name plate and pressure gauge: PS
	Digital pressure switch: with unit switching (MPa is initially se	
	,	option is available for use outside Japan only. (The SI unit has to be u apan.)
	Note 2) The	digital pressure switch is equipped with unit switching and initially set to
	Note 3) This option is available with the digital pressure switch.	

4. Digital Presure Switch



Made to Order

Series ARM10/11 Safety Instructions

These safety instructions are intended to prevent a hazardous situation and/or equipment damage. These instructions indicate the level of potential hazard by labels of **"Caution"**, **"Warning"** or **"Danger"**. To ensure safety, be sure to observe ISO 4414 ^{Note 1}, JIS B 8370 ^{Note 2}) and other safety practices.

Explanation of the Labels

Labels	Explanation of the labels	
Danger In extreme conditions, there is a possible result of serious injury or loss of life.		
\land Warning	Warning Operator error could result in serious injury or loss of life.	
Caution Operator error could result in injury Note 3) or equipment damage Note 4).		

Note 1) ISO 4414: Pneumatic fluid power - General rules relating to systems

Note 2) JIS B 8370: General Rules for Pneumatic Equipment

Note 3) Injury indicates light wounds, burns and electrical shocks that do not require hospitalisation or hospital visits for long-term medical treatment.

Note 4) Equipment damage refers to extensive damage to the equipment and surrounding devices.

Selection/Handling/Applications

1. The compatibility of the pneumatic equipment is the responsibility of the person who designs the pneumatic system or decides its specifications.

Since the products specified here are used in various operating conditions, their compatibility for the specific pneumatic system must be based on specifications or post analysis and/or tests to meet the specific requirements. The expected performance and safety assurance are the responsibility of the person who has determined the compatibility of the system. This person should continuously review the suitability of all items specified, referring to the latest catalogue information with a view to giving due consideration to any possibility of equipment failure when configuring a system.

- **2. Only trained personnel should operate pneumatically operated machinery and equipment.** Compressed air can be dangerous if handled incorrectly. Assembly, handling or repair of pneumatic systems should be performed by trained and experienced operators. (Understanding JIS B 8370 General Rules for Pneumatic Equipment, and other safety rules are included.)
- **3.** Do not service machinery/equipment or attempt to remove components until safety is confirmed. 1. Inspection and maintenance of machinery/equipment should only be performed once measures to prevent falling or runaway
 - and maintenance of machinely/equipment should only be performed once measures to prevent failing of runaway of the driver objects have been confirmed.
 When equipment is removed, confirm that safety process as mentioned above. Turn off the supply pressure for this equipment.
 - and exhaust all residual compressed air in the system, and release all the energy (liquid pressure, spring, condenser, gravity).Before machinery/equipment is restarted, take measures to prevent quick extension of a cylinder piston rod, etc.
- 4. Contact SMC if the product will be used in any of the following conditions:
 - 1. Conditions and environments beyond the given specifications, or if product is used outdoors.
 - 2. Installation on equipment in conjunction with atomic energy, railway, air navigation, vehicles, medical equipment, food and beverages, recreation equipment, emergency stop circuits, clutch and brake circuits in press applications, or safety equipment.
 - An application which has the possibility of having negative effects on people, property, or animals, requiring special safety analysis.
 If the products are used in an interlock circuit, prepare a double interlock style circuit with a mechanical protection function for the prevention of a breakdown. And, examine the devices periodically if they function normally or not.

■ Exemption from Liability

- 1. SMC, its officers and employees shall be exempted from liability for any loss or damage arising out of earthquakes or fire, action by a third person, accidents, customer error with or without intention, product misuse, and any other damages caused by abnormal operating conditions.
- 2. SMC, its officers and employees shall be exempted from liability for any direct or indirect loss or damage, including consequential loss or damage, loss of profits, or loss of chance, claims, demands, proceedings, costs, expenses, awards, judgments and any other liability whatsoever including legal costs and expenses, which may be suffered or incurred, whether in tort (including negligence), contract, breach of statutory duty, equity or otherwise.
- 3. SMC is exempted from liability for any damages caused by operations not contained in the catalogues and/or instruction manuals, and operations outside of the specification range.
- 4. SMC is exempted from liability for any loss or damage whatsoever caused by malfunctions of its products when combined with other devices or software.





Series ARM10/11 **Compact Manifold Regulator Specific Product Precautions 1**

Be sure to read this before handling.

Design & Selection

🗥 Warning

1. Confirm the specifications.

The products appearing in this catalogue are designed for use only in compressed air systems.

Do not use outside the specified ranges of pressure, temperature, etc., as this may cause damage or faulty operation. Please consult with SMC if fluid other than compressed air is to be used.

2. Do not use the products in this catalogue as "safety accessories" stipulated in Art. 1, paragraph 2.1.3 and Art. 3, paragraph 1.4 of Pressure Equipment Directive (97/23/EC).

The Pressure Equipment Directive defines a safety accessory as a device which is designed to prevent pressure equipment from exceeding the allowable limit values.

3. Confirm the regulating pressure range.

Be sure to install safety devices as an output pressure above the set range can lead to damage or malfunction of equipment on the outlet side.

4. Residual pressure relief without inlet pressure.

In cases where the inlet pressure has been released while the outlet pressure is in a low-pressure setting state, it may not be possible to exhaust the outlet pressure (residual pressure relief). Provide a residual pressure relief circuit if reliable outlet pressure relief must be performed.

5. When used with a closed downstream circuit and balance circuit.

Please contact SMC as there are cases in which the product cannot be used.

Mounting

\land Warning

- 1. Read the instruction manual carefully. The product should be mounted and operated with a good understanding of its contents. Also, keep the manual where it
- can be easily referred to at any time. 2. Ensure space for maintenance.

Ensure the necessary space for maintenance activities.

3. Strictly observe the tightening torque of the screw.

Tighten the screw at the recommended torque in installation.

Piping

▲Caution

Precautions in use of One-touch fittings

1) Tubing installation

- 1. Take a tubing with no flaws on its periphery and cut it off at a right angle. Use a TK-1, 2 or 3 tubing cutter to cut the tubing. Do not use pinchers, nippers or scissors, etc. The tubing might be cut diagonally or flattened, making installation impossible or causing problems such as disconnection and leakage. Also, ensure sufficient tubing length.
- 2. Hold the tubing and push it in slowly, inserting it securely all the way into the fitting.

Piping

▲ Caution

- 3. After inserting the tubing, pull it lightly to confirm that it will not come out. If the tubing is not inserted to the end, air leakage or disconnection may occur.
- 4. When piping, increase the length of the tubing to allow for any possible warping, increased tension or moment load, etc. to the fittings and tubing.

2) Tubing removal

- 1. Push both the release bushing and flange.
- 2. Pull out the tubing while holding the release bushing so that it will not be locked again. Insufficient pressure on the release bushing will result in increased biting force that will impede the tubing removal.
- 3. When re-using a removable tubing, cut off the deformed part. If the deformed part of the tubing is used, it can cause air leakage or impede the tubing removal.

In cases where a tubing brand other than SMC is used, confirm that the tubing outside diameter accuracy satisfies the following specifications.

- 1. Nylon tubing
- ±0.1 mm or less 2. Soft nylon tubing ±0.1 mm or less
- 3. Polyurethane tubing +0.15 mm or less/-0.2 mm or less

Do not use the tubing if it does not satisfy the outside diameter accuracy. Tubing connection may be impossible or air leakage or tubing disconnection may occur after connection.

Air Supply

🗥 Warning

1. Use clean air.

Do not use the regulator if the compressed air contains synthetic oil including chemicals or organic solvents, salt or corrosive gas. It may lead to damage or malfunction.

▲ Caution

1. Install an air filter.

Install an air filter on the inlet side in close proximity to the regulator. Select a type with 5 µm or smaller filtration.

- 2. Install an after cooler, air dryer or mist separator (drain catch) to remove drainage. Compressed air containing excessive drainage may cause malfunction of the regulator, pressure switch or other pneumatic equipment.
- 3. If an excessive amount of carbon powder is generated, install a mist separator as a measure. If an excessive amount of carbon powder is generated from the compressor, it may adhere to the interior of the regulator and cause malfunction.

Refer to SMC's Best Pneumatics catalogue for further details on compressed air quality.





Series ARM10/11 Compact Manifold Regulator Specific Product Precautions 2

Be sure to read this before handling.

Operating Environment

Warning

- 1. Do not operate in locations having an atmosphere of corrosive gases, chemicals, sea water, fresh water or water vapor, or where there will be contact with the same.
- 2. In locations which receive direct sunlight, the sunlight should be blocked.
- 3. Do not operate in locations where vibration or impact occurs.
- 4. Do not operate in a location near a heat source or where radiated heat will be received.

Adjustment

A Warning

Regulator

- **1.** Set up the regulator while verifying the pressure that is indicated on the inlet side and outlet side pressure gauges. Turning the handle excessively could damage the internal parts.
- **2.** The adjustment handle must be operated manually. Using a tool to turn the handle could lead to damage.

ACaution

Regulator

- 1. Set up the regulator after carefully verifying the pressure that is indicated on the inlet side pressure gauge.
- 2. Set the outlet pressure in a range that is within 85% of the inlet pressure.

Also, it should not exceed the set pressure range.

- 3. Release the lock to adjust the pressure. After the adjustment, engage the lock. Failure to observe this procedure could damage the handle or cause the outlet pressure to fluctuate.
- 4. Turning the pressure adjustment handle clockwise increases the outlet pressure and turning it counterclockwise decreases the pressure. (To achieve the final set pressure, gradually increase from a low pressure until the desired pressure is reached).

Adjustment

▲Caution

How to adjust indicator of the pressure gauge.

Make sure to follow the instructions below when opening the lens cover to adjust the pressure gauge.


1. Open the lens cover to the arrow's direction with finger nail.



2. Adjust the gauge needle with for example, a flat head screw driver.



3. Close the lens cover to the arrow's direction until it snaps on.



Maintenance

1. Maintenance should be performed according to the procedure indicated in the instruction manual.

Improper handling can cause damage and malfunction of equipment and machinery.

2. Maintenance operations

Improper handling of compressed air is dangerous. Therefore, in addition to observing the product specifications, replacement of elements and other maintenance activities should be performed by personnel having sufficient knowledge and experience pertaining to pneumatic equipment.

3. Pre-maintenance inspection

When removing this product, turn off the electric power, and be certain to shut off the supply pressure and exhaust the compressed air in the system. Proceed only after confirming that all pressure has been released to the atmosphere.

4. Post maintenance inspection

After installation or repair, reconnect compressed air and electricity and conduct appropriate inspections to confirm proper operation. If there is an audible air leakage, or if the equipment does not operate properly, stop operation and confirm that the equipment is installed correctly.

5. Modification is prohibited.

Do not modify or reconstruct the unit.



\triangle

Series ARM10/11

Blocks Specific Product Precautions 1

Be sure to read this before handling.

Handling


Marning

Observe the proper screw tightening torques during the installation.


Tightening beyond the proper tightening torque may damage the mounting screws, blocks or switches.

If the force is below the tightening torque range, the threaded joint can come loose.


1. Tightening torque for the fixing screws and panel nuts of a single unit regulator.




2. Tightening torque for the regulator assembly fixing screws on aregulator block.



3. Tightening torque for the blanking plates and pressure gauge fixing screws on a regulator block.



4. Tightening torque for the pressure switch fixing screws on a common supply block with pressure switch and/or pressure switch block.



5. Tightening torque for DIN rail clamp screws on end blocks. $\underbrace{1.5 \pm 0.15 \text{ N} \cdot \text{m}}_{1.5 \pm 0.15 \text{ N} \cdot \text{m}}$



MWarning

Digital Pressure Switch


Mount it with the proper screw-tightening torque.

Overtightening may damage the regulator body or adaptor, etc. Meanwhile, insufficient tightening may loosen the connecting threads.

- 1. Attach an O-ring to the regulator O-ring slit.
- 2. Attach the adaptor with the 2 set screws by positioning the adapter slot on the opposite side of the handle and keeping the 2 square nuts (right/left) attached.

Tightening torque: 0.32 \pm 0.03 N·m

- 3. Attach the switch body.
- **4. Fully insert the locking pin into the adapter slot.** The switch body can be replaced by attaching/removing the locking pin.



\triangle

Series ARM10/11

Blocks Specific Product Precautions 2


Be sure to read this before handling.

≜Caution


One-touch fitting replacement

For the ease of replacement, One-touch fittings are installed as the cassette type. One-touch fittings are retained with clips inserted from the directions illustrated blow. Remove the clips with a flat head screw driver to replace the One-touch fittings. When installing, insert each One-touch fitting deeply to the end and reinsert the clip to the specified position.


1. Single unit regulator



2. Regulator block




3. Various common supply blocks



ACaution

Pressure supply of 3-way valve common supply block

Make sure that the handle is set at the OPEN or SHUT position in operation. The block cannot be used for the purpose of containing pressure because it allows a small amount of leakage.



Handling


≜Caution

• Digital Pressure Switch How to attach a connector

Insert the connector vertically onto the pins, pinching the lever and connector with your fingers. Insert the lever into the switch body slot until it is locked.

How to remove a connector

Pull the lever straight forward by pushing its claw to remove it from the slot.







Series ARM10/11 Pressure Switches Specific Product Precautions 3

Be sure to read this before handling.

Design & Selection

Marning

- **1. Operate the switch only within the specified voltage.** Use of the switch outside the range of the specified voltage can cause malfunction and damage to the switch, it may also increase the risks of electrical shocks or fire.
- 2. Never apply a load above the maximum load capacity. It can damage the switch or shorten the service life.
- 3. Be sure to observe the set pressure range and maximum operating pressure.

Use of the switch outside the set pressure range can cause failure and use beyond the maximum operating pressure can damage the switch.

Mounting

Warning

1. Do not use the switch unless the equipment operates normally.

After installation, repair or reform, connect air and electricity and conduct appropriate function and leakage tests to confirm proper installation.

2. Do not apply a tensile force to a cord.

Be sure to hold the body to handle the product. Applying a tensile force to a cord may cause damage to the product.

3. Do not drop or bump the product.

Dropping or bumping while handling may cause damage to the product.

Pressure Supply

AWarning

- Do not use the switch with corrosive gas or liquid. Do not use the switch with corrosive gas or liquid. Such gas or fluid may cause damage to the switch.
- 2. Do not use the switch at a vacuum pressure. If used in a vacuum pressure range, the switch will suction the outer air and become unable to operate.

Pressure Setting

ACaution

- 1. The switching setting indication scale shows the set value for pressure decrease.
- 2. When the ON pressure signal is to be detected, the ON signal comes on at the pressure found by adding the hysteresis to the pressure set on the scale plate.
- 3. The pressure indication on the scale plate is provided as a guideline. Use a pressure gauge to measure the precise settings.

Wiring

A Warning

1. Connect the load


Be sure to connect the load to the pressure switch before connecting the power supply.

2. Use a contact protection box.

If the load driven by the pressure switch is an induction load or connected with a lead wire of 5 m or longer, use a contact protection box in the following table.

Contact protection box	Operating voltage	Lead wire length
CD-P11	100 VAC	Switch connection side: 0.5 m
CD-P12	24 VDC	Load connection side: 0.5 m

3. Contact protection box internal circuit



4. Contact protection box/Connection method

To connect the switch body and the contact protection box, connect the lead wire of the contact protection box on the side marked with "SWITCH" and the lead wire from the switch body. Connect the switch body and the contact protection box with a lead wire of 1 m or shorter and arrange them as close as possible.

5. Lead wire dimensions

Covering: ø3.4 Insulator: ø1.1 Conductor: ø0.64

Operating Environment

A Warning

1. Never use in the presence of explosive gases.

These switches are not rated as explosion proof. Never use in the presence of an explosive gas as this may cause a serious explosion.

2. Do not use in an environment where a strong magnetic field is present.

The influence of the external magnetic filed may cause the switch to malfunction.

3. Do not use in an environment where the switch is exposed to water or oil splashes.

Because the switch has an open type construction, ingress of water or oil can corrode the electric circuit, resulting in malfunction and damage.

4. Do not apply vibration to the switch.

If vibration is applied, malfunction or setting errors may result.





EUROPEAN SUBSIDIARIES:

Austria

SMC Pneumatik GmbH (Austria). Girakstrasse 8, A-2100 Korneuburg Phone: +43 2262-62280, Fax: +43 2262-62285 E-mail: office@smc.at http://www.smc.at



Belgium

SMC Pneumatics N.V./S.A. Nijverheidsstraat 20, B-2160 Wommelgem Phone: +32 (0)3-355-1464, Fax: +32 (0)3-355-1466 E-mail: post@smcpneumatics.be http://www.smcpneumatics.be



Bulgaria SMC Industrial Automation Bulgaria EOOD 16 kliment Ohridski Blvd., fl.13 BG-1756 Sofia Phone:+359 2 9744492, Fax:+359 2 9744519 E-mail: office@smc.bg http://www.smc.bg



Croatia

SMC Industrijska automatika d.o.o. Crnomerec 12, 10000 ZAGREB Phone: +385 1 377 66 74, Fax: +385 1 377 66 74 E-mail: office@smc.hr http://www.smceu.com



Czech Republic SMC Industrial Automation CZ s.r.o. Hudcova 78a, CZ-61200 Brno Phone: +420 5 414 24611, Fax: +420 5 412 18034 E-mail: office@smc.cz http://www.smc.cz



Denmark

SMC Pneumatik A/S Knudsminde 4B, DK-8300 Odder Phone: +45 70252900, Fax: +45 70252901 E-mail: smc@smc-pneumatik.dk http://www.smcdk.com



SMC Pneumatics Estonia OÜ Laki 12-101, 106 21 Tallinn Phone: +372 (0)6 593540, Fax: +372 (0)6 593541 E-mail: smc@smcpneumatics.ee http://www.smcpneumatics.ee



SMC Pneumatics Finland OY PL72, Tiistinniityntie 4, SF-02031 ESPOO Phone: +358 207 513513, Fax: +358 207 513595 E-mail: smcfi@smc.fi http://www.smc.fi



OTHER SUBSIDIARIES WORLDWIDE:

ARGENTINA, AUSTRALIA, BOLIVIA, BRASIL, CANADA, CHILE, CHINA, HONG KONG, INDIA, INDONESIA, MALAYSIA, MEXICO, NEW ZEALAND, PHILIPPINES, SINGAPORE, SOUTH KOREA, TAIWAN, THAILAND, USA, VENEZUELA

France

SMC Pneumatique, S.A. 1, Boulevard de Strasbourg, Parc Gustave Eiffel Bussy Saint Georges F-77607 Marne La Vallee Cedex 3 Phone: +33 (0)1-6476 1000, Fax: +33 (0)1-6476 1010 E-mail: contact@smc-france.fr http://www.smc-france.fr



Germany

SMC Pneumatik GmbH Boschring 13-15, D-63329 Egelsbach Phone: +49 (0)6103-4020, Fax: +49 (0)6103-402139 E-mail: info@smc-pneumatik.de http://www.smc-pneumatik.de

Greece

S. Parianopoulus S.A 7, Konstantinoupoleos Street, GR-11855 Athens Phone: +30 (0)1-3426076, Fax: +30 (0)1-3455578 E-mail: parianos@hol.gr http://www.smceu.com



Hungary SMC Hungary Ipari Automatizálási Kft. Budafoki ut 107-113, H-1117 Budapest Phone: +36 1 371 1343, Fax: +36 1 371 1344 E-mail: office@smc-automation.hu http://www.smc-automation.hu

Ireland

SMC Pneumatics (Ireland) Ltd. 2002 Citywest Business Campus, Naas Road, Saggart, Co. Dublin Phone: +353 (0)1-403 9000, Fax: +353 (0)1-464-0500 E-mail: sales@smcpneumatics.ie http://www.smcpneumatics.ie



SMC Italia S.p.A Via Garibaldi 62, I-20061Carugate, (Milano) Phone: +39 (0)2-92711, Fax: +39 (0)2-9271365 E-mail: mailbox@smcitalia.it http://www.smcitalia.it



Latvia SMC Pneumatics Latvia SIA Smerla 1-705, Riga LV-1006, Latvia Phone: +371 781-77-00, Fax: +371 781-77-01 E-mail: info@smclv.lv http://www.smclv.lv



SMC Pneumatics Lietuva, UAB Savanoriu pr. 180, LT-01354 Vilnius, Lithuania Phone: +370 5 264 81 26, Fax: +370 5 264 81 26

Netherlands SMC Pneumatics BV

De Ruyterkade 120, NL-1011 AB Amsterdam Phone: +31 (0)20-5318888, Fax: +31 (0)20-5318880 E-mail: info@smcpneumatics.nl http://www.smcpneumatics.nl



SMC Pneumatics Norway A/S Vollsveien 13 C, Granfos Næringspark N-1366 Lysaker Tel: +47 67 12 90 20, Fax: +47 67 12 90 21

E-mail: post@smc-norge.no http://www.smc-norge.no



SMC Industrial Automation Polska Sp.z.o.o. ul. Konstruktorska 11A, PL-02-673 Warszawa, Phone: +48 22 548 5085, Fax: +48 22 548 5087 E-mail: office@smc.pl http://www.smc.pl



Portugal

SMC Sucursal Portugal, S.A. Rua de Eng^e Ferreira Dias 452, 4100-246 Porto Phone: +351 22-610-89-22, Fax: +351 22-610-89-36 E-mail: postpt@smc.smces.es http://www.smces.es

Romania

SMC Romania srl Str Frunzei 29, Sector 2, Bucharest Phone: +40 213205111, Fax: +40 213261489 E-mail: smcromania@smcromania.ro http://www.smcromania.ro



Russia SMC Pneumatik LLC. 4B Sverdlovskaja nab, St. Petersburg 195009 Phone.:+812 718 5445, Fax:+812 718 5449 E-mail: info@smc-pneumatik.ru http://www.smc-pneumatik.ru



Slovakia SMC Priemyselná Automatizáciá, s.r.o. Námestie Martina Benku 10, SK-81107 Bratislava Phone: +421 2 444 56725, Fax: +421 2 444 56028 E-mail: office@smc.sk http://www.smc.sk





SMC España, S.A. Zuazobidea 14, 01015 Vitoria Phone: +34 945-184 100, Fax: +34 945-184 124 E-mail: post@smc.smces.es http://www.smces.es



SMC Pneumatics Sweden AB Ekhagsvägen 29-31, S-141 71 Huddinge Phone: +46 (0)8-603 12 00, Fax: +46 (0)8-603 12 90 E-mail: post@smcpneumatics.se http://www.smc.nu



Switzerland SMC Pneumatik AG Dorfstrasse 7, CH-8484 Weisslingen Phone: +41 (0)52-396-3131, Fax: +41 (0)52-396-3191

E-mail: info@smc.ch http://www.smc.ch



Entek Pnömatik San. ve Tic Ltd. Sti. Perpa Tic. Merkezi Kat: 11 No: 1625, TR-80270 Okmeydani Istanbul Phone: +90 (0)212-221-1512, Fax: +90 (0)212-221-1519 E-mail: smc-entek@entek.com.tr http://www.entek.com.tr



SMC Pneumatics (UK) Ltd Vincent Avenue, Crownhill, Milton Keynes, MK8 0AN Phone: +44 (0)800 1382930 Fax: +44 (0)1908-555064 E-mail: sales@smcpneumatics.co.uk http://www.smcpneumatics.co.uk







SMC industrijska Avtomatika d.o.o. Grajski trg 15, SLO-8360 Zuzemberk Phone: +386 738 85240 Fax: +386 738 85249 E-mail: office@smc-ind-avtom.si http://www.smc-ind-avtom.si

http://www.smceu.com http://www.smcworld.com

SMC CORPORATION Akihabara UDX 15F, 4-14-1, Sotokanda, Chiyoda-ku, Tokyo 101-0021, JAPAN Phone: 03-5207-8249 FAX: 03-5298-5362 1st printing KQ printing KQ 00 UK Printed in Spain



