



## **Declaration of Conformity**

For the following equipmer	nt :		
Product Name: Din-Rail Switching Power Supply			
Model Designation: MDR-x-y (x=40, 60; y=5, 12, 24, 48)			
is herewith confirmed to c were applied :	comply with the requirements se	t out in the Council	Directive, the following standards
RoHS Directive (2011	/65/EU)		
Low Voltage Directive (	(2014/35/EU) :		
EN60950-1:2006+A11+A1+A12+A2 TUV certificate No : R50100751			: R50100751
Electromagnetic Comp EMI (Electro-Magnetic In Conducted emission / Rad		/EU) :	Class B
Harmonic current	EN61000-3-2:2014		
Voltage flicker	EN61000-3-3:2013		
EMS (Electro-Magnetic S	Susceptibility)		
EN55024:2010+A1:2015			
ESD air	EN61000-4-2:2009	Level 3	8KV
ESD contact	EN61000-4-2:2009	Level 2	4KV
RF field susceptibility	EN61000-4-3:2006+A1:2008+	A2:2010 Level 3	10V/m
EFT bursts	EN61000-4-4:2012	Level 3	2KV/5KHz
Surge susceptibility	EN61000-4-5:2014	Level 4	2KV/Line-Line
Surge susceptibility	EN61000-4-5:2014	Level 4	4KV/Line-Earth
Conducted susceptibility	EN61000-4-6:2014	Level 3	10V
Magnetic field immunity	EN61000-4-8:2010	Level 4	30A/m
Voltage dip, interruption	EN61000-4-11:2004 >95% dip 0.5	5 periods 30% dip 25	periods >95% interruptions 250 periods
Note: The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.  For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).			
This Declaration is effective from serial number EB7xxxxxxx			
Person responsible for marking this declaration :			
MEAN WELL Enterprises (	Co., Ltd.		
(Manufacturer Name) No.28, Wuquan 3rd Rd., W	/ugu Dist., New Taipei City 248,	Taiwan	
(Manufacturer Address)			
Johnny Huang/Manager, Certific (Name / Position)	cation Center : Clum (Signature)	Alex Tsai/Director, Mar (Name / Position)	keting Department: (Signature)
Taiwan (Place)	Apr. 7th ,2017		
(Place)	(Date)		