



Certificate of Compliance

Certificate Number: LR 16186-49

Revision: LR 16186-57

Date Issued: January 27, 1997

Issued To: E-T-A CIRCUIT BREAKERS LTD.
236 Hood Rd.
Markham, ON L3R 3K8
Attention: Mr. Tony Bright

The products listed below are eligible to bear the CSA Mark.

Issued By: S. Jeffery, C.E.T.
Toronto, Ontario/Canada

Signature

CLASS

3215 01 - SUPPLEMENTARY PROTECTORS

PRODUCTS

Supplementary protectors, Type 41-27, 127, 41-57, 157, 41-58, 158, 45-000, 2-5000, 45-700, 2-5700, 16A, 250V ac, 28V ac.

Note: These devices are Certified as components for use only in other Certified equipment where the suitability of the combination is to be determined by the Canadian Standards Association.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 235-M89 Supplementary Protectors

MARKINGS

The submitter's name or tradename "E-T-A", complete catalogue designation, complete electrical rating, volts and amperes, terminal numbering, delay curve identification and CSA Monogram are either moulded in or ink-stamped on the protector bodies.