

QQGQ2.E152784

Power Supplies, Information Technology Equipment Including Electrical Business Equipment - Component

Power Supplies, Information Technology Equipment Including Electrical Business Equipment - Component

See General Information for Power Supplies, Information Technology Equipment Including Electrical
Business Equipment - Component

OMRON CORP

E152784

SAFETY STANDARDS GROUP

IAB TECHNOLOGY DEVELOPMENT CENTER H Q

SHIOKOJI HORIKAWA, SHIMOGYO-KU

KYOTO 600-8530, JAPAN

Model No.	Rated Input			Max Output			OC	SP	EP	FC	GC
	Volts	Hz	SC	V	A	VA					
S82H-100 (+)											
	100-120/ 200-240ac	50/60	0	5dc	20	-	3	60950-1	5B	5	1
				12dc	9	-	3				
				15dc	7.2	-	3				
				24dc	4.6	-	3				
S82H-150 (+)											
	100-120/ 200-240ac	50/60	0	5dc	30	-	3	60950-1	7B	5	1
				12dc	13.5	-	3				
				15dc	10	-	3				
				24dc	7	-	3				
S82J-01005(g)											
	100-120/ 200-240ac	50/60	0	5	2	10	1	60950-1	-	0	0
S82J-01012(g)											
	100-120/ 200-240ac	50/60	0	12	1	10	1	60950-1	-	0	0

S82J-01015(g)											
	100-120/ 200-240ac	50/60	0	15	0.7	10	1	60950-1	-	0	0
S82J-01024(g)											
	100-120/ 200-240ac	50/60	0	24	0.5	10	1	60950-1	-	0	0
S82J-02505											
	100-120/ 200-240ac	50/60	0	5	5	25	4	60950-1	-	0	0
S82J-02512(g)											
	100-120/ 200-240ac	50/60	0	12	2.1	25	1	60950-1	-	0	0
S82J-02515(g)											
	100-120/ 200-240ac	50/60	0	15	1.7	25	1	60950-1	-	0	0
S82J-02524(g)											
	100-120/ 200-240ac	50/60	0	24	1.1	25	1	60950-1	-	0	0
S82J-05005											
	100-120/ 200-240ac	50/60	0	5	10	50	4	60950-1	-	0	0
S82J-05012											
	100-120/ 200-240ac	50/60	0	12	4.2	50	4	60950-1	-	0	0
S82J-05024(g)											
	100-240ac	50/60	2	24	2.1	50	4	60950-1	-	0	0
S82J-10005(e)(f)											
	100-120/ 200-240ac	50/60	0	5	20	100	4	60950-1	-	0	0
S82J-10012(e)(f)											
	100-120/ 200-240ac	50/60	0	12	8.5	100	4	60950-1	-	0	0
S82J-10015(e)(f)											
	100-120/ 200-240ac	50/60	0	15	7	100	4	60950-1	-	0	0
S82J-10024											
	100-240ac	50/60	0	24	4.5	100	4	60950-1	-	0	0
S82J-15024											
	100-120/ 200-240ac	50/60	0	24	6.5	150	4	60950-1	-	0	0

	100-240ac	50/60	0	24	27	648	3	1950	-	0	0
S8T-DCBU-01											
	24dc	-	4	24	8	172	3	60950-1	-	0	0
S8T-DCBU-02											
	24dc	-	4	22.5	2.69	70.4	3	60950-1	-	0	0
S8TS-02505[*r]											
	100-240ac	50/60	0	5	5	-	3	1950	-	0	0
S8TS-03012[*r]											
	100-240ac	50/60	0	12	2.5	-	3	1950	-	0	0
S8TS-06024[*r]											
	100-240ac	50/60	0	24	2.5	-	3	1950	-	0	0
S8VS-01505											
	100-240ac	50/60	0	5	2	10	4	60950-1	3.15	0	1
S8VS-01512											
	100-240ac	50/60	0	12	1.2	14.4	4	60950-1	3.15	0	1
S8VS-01524											
	100-240ac	50/60	0	24	0.65	15.6	4	60950-1	3.15	0	1
S8VS-03005											
	100-240ac	50/60	0	5	4	20	4	60950-1	3.15	0	1
S8VS-03012											
	100-240ac	50/60	0	12	2.5	30	4	60950-1	3.15	0	1
S8VS-03024											
	100-240ac	50/60	0	24	1.3	31.2	4	60950-1	3.15	0	1
S8VS-06024(c)(e), S8VS-06024A(c)(e), S8VS-06024B(c)(e)											
	100-240ac	50/60	0	24.1	2.9	68	3	60950	-	0	0
S8VS-09024(c)(e), S8VS-09024A(c)(e), S8VS-09024B(c)(e)											
	100-240ac	50/60	0	24.2	4.3	103	3	60950	-	0	0
S8VS-12024(c)(e), S8VS-12024A(c)(e), S8VS-12024B(c)(e)											
	100-240ac	50/60	0	24.3	5.25	127	3	60950	-	0	0
S8VS-18024(c)(e), S8VS-18024A(c)(e), S8VS-18024B(c)(e)											
	100-240ac	50/60	0	29.55	8.15	226	3	60950-1	-	0	0
S8VS-24024(c)(e), S8VS-24024A(c)(e), S8VS-24024B(c)(e)											
	100-240ac	50/60	0	28.65	11.2	305	3	60950	-	0	0
ZEN-PA03024(c)(e)											
	100-240ac	50/60	0	29.6	1.62	47	3	60950-1	20B	0	2

[*r] - Output values are rated.

(#) - Followed by additional numbers or a blank.

(+) - followed by 05, 12, 15, or 24; may be followed by an additional number from 300 through 999.

(c) - May be followed by P, may be followed by an additional three digit number 300 - 999 inclusive, or a blank.

(d) - Complementary Recognized to Power Supplies, Specialty-Component (QQIJ2), File E105544.

(e) - Complementary Recognized under UL 508.

(f) - Complementary Recognized under UL 1012.

(g) - Complementary Recognized under UL 1310.

Marking: Company name and model designation.

Last Updated on 20041110

This page and all contents are Copyright © 2004 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2004 Underwriters Laboratories Inc.®"

QQGQ2.GuideInfo

Power Supplies, Information Technology Equipment Including Electrical Business Equipment - Component

[Power Supplies - Component] Power Supplies, Information Technology Equipment Including Electrical Business Equipment - Component

Guide Information

The devices covered under this category are incomplete in certain constructional features or restricted in performance capabilities and are intended for use as components of complete equipment submitted for investigation rather than for direct separate installation in the field. THE FINAL ACCEPTANCE OF THE COMPONENT IS DEPENDENT UPON ITS INSTALLATION AND USE IN COMPLETE EQUIPMENT SUBMITTED TO UNDERWRITERS LABORATORIES INC.

GENERAL

This category covers component power supplies intended for use in/with information processing and business equipment. End-use products that employ these types of power supplies are covered under Information Technology Equipment Including Electrical Business Equipment (**NWGO**).

Codes

The following summarizes and defines codes shown in the individual Recognitions in addition to those indicated under Power Supplies (**QQAQ2**).

Supply Category (SC) — Code identifies the type of supply to which the component is intended to be connected.

SC Categories	Code
Branch circuit power	0
NEC Class 2	1
Isolated extra low voltage (ELV)*	2
Isolated safety extra low voltage (SELV)*	3
Isolated secondary circuit	4
Limited energy isolated secondary circuit	5
Centralized DC	6

Maximum Voltage (Max V) — The maximum output voltage under any resistive loading condition is indicated in volts peak.

Maximum Amperes (Max A) — The maximum output current under any resistive loading condition is indicated in amperes rms.

Maximum Volt (Max VA) — The maximum output volt-amperes under any resistive loading condition is indicated in volt-amperes rms.

Output Category (OC) — Each output is identified to indicate the type of output.

OC Categories	Code
NEC Class 1	0
NEC Class 2	1
Isolated extra low voltage (ELV)*	2
Isolated safety extra low voltage (SELV)*	3
Isolated secondary circuit	4
* ELV and SELV are defined in UL 60950 and UL 60950-1	

Spacings (SP) — The standard used in judging spacings (or creepage and clearance distances) is indicated by the Standard No.

External Protection (EP) — Tests on the component were conducted with the primary protected by external overcurrent protection.

EP Categories	Code
Specified current rating, branch protection	@B
Specified current rating, time delay fuse	@T
Specified current rating, not branch protection	@
(@) Indicates current rating of protection in amperes	

Field Connections (FC) — Code indicates whether supply and output connections have been investigated for field connections.

FC Categories	Code
Supply and output not investigated for FC	0
Supply not investigated for FC	1
Output not investigated for FC	2
Supply suitable for FC (+)	3
Output suitable for FC (+)	4
Supply and output suitable for FC (+)	5
Supply suitable for FC (++)	6
Output suitable for FC (++)	7
Supply and output suitable for FC (++)	8
(+) Employs pressure wire terminals or terminal block suitable for field wiring	
(++) Employs a connector, or a cord terminating in a connector	

Grounding Connection (GC) — Units with functional grounding connections (no safety grounding connection) shall have dead metal parts bonded to the end-product grounding means.

GC Categories	Code
Only functional grounding provided	0
Provided with safety grounding connection	1
Double insulated product	2

REBUILT PRODUCTS

This category also covers Recognized Component power supplies that are rebuilt by the original manufacturer or another party having the necessary facilities, technical knowledge and manufacturing skills. Rebuilt power supplies are rebuilt to the extent necessary by disassembly and reassembly using new or reconditioned parts. Rebuilt power supplies are subject to the same requirements as new power supplies.

RELATED PRODUCTS

See Power Supplies, General Purpose (QQFU2).

ADDITIONAL INFORMATION

For additional information, see Power Supplies (QQAQ2).

REQUIREMENTS

The basic standards currently used to investigate products in this category are UL 60950 or UL 60950-1, "Safety of Information Technology Equipment."

UL MARKING

Products Recognized under UL's Component Program are identified by significant markings consisting of the manufacturer's identification and catalog, model or other product designation which correspond with the marking specified in UL's published records. Only those components which actually bear the "Marking" shown in the individual Recognitions should be considered as being covered under the Component Program.

For rebuilt products the word "Rebuilt," "Remanufactured" or "Reconditioned" precedes the product name.

The Listing or Classification Mark of Underwriters Laboratories Inc. is not authorized for use on, or in connection with, Recognized Components.

This page and all contents are Copyright © 2004 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2004 Underwriters Laboratories Inc.®"

QQAQ2.GuideInfo Power Supplies - Component

Power Supplies - Component

These recognitions cover the following products:

Power Supplies for use in Electronic Data Processing Equipment

Power Supplies for use in Electrostatic Air Cleaning Equipment

Gas Tube Sign Power Supplies

General Purpose Power Supplies

Power Supplies for use in Information Technology Equipment, Including

Electrical Business Equipment

Power Supplies for use in Medical and Dental Equipment

Power Supplies for use in Office Appliances and Business Equipment

Specialty Power Supplies

Telephone Power Supplies

The devices covered under this category are incomplete in certain constructional features or restricted in performance capabilities and are intended for use as components of complete equipment submitted for investigation rather than for direct separate installation in the field. THE FINAL ACCEPTANCE OF THE COMPONENT IS DEPENDENT UPON ITS INSTALLATION AND USE IN COMPLETE EQUIPMENT SUBMITTED TO UNDERWRITERS LABORATORIES INC.

Power supplies evaluated in accordance with IEC publications are indicated in this directory under Power Supplies Evaluated in Accordance with IEC Publications, Guide QOKV2.

These categories do not include power supplies intended as components of fire protection or burglary protective signaling systems.

Unless specified otherwise in the individual recognitions, consideration is to be given to the following conditions of acceptability when these components are employed in end-use products. Absence of ratings and condition of acceptability codes from an individual recognition indicates this information is contained in the UL Recognition report for the product.

1) Codes - The following summarizes and defines codes shown in the individual recognitions. If not applicable, a "-" (dash) is indicated in the individual recognition. Unique conditions of acceptability are indicated in individual recognitions.

Supply category (SC) - Code identifies the type of supply to which the component is intended to be connected. Refer to guides of individual categories below for SC codes.

Maximum Voltage (Max V) - The maximum output voltage under any resistive loading condition is indicated in volts peak.

Maximum Amps (Max A) - The maximum output current under any resistive loading condition is indicated in amps rms.

Maximum Volt - Amps (Max VA) - The maximum output volt-amperes under any resistive loading condition is indicated in volt-amperes rms.

Output category (OC) - Each output is identified to indicate the type of output. Refer to guides of individual categories below for OC codes. Convenience receptacles connected to the supply circuit are not considered outputs, however, these are to be loaded to determine the overall heating effect in the application.

Spacings (SP) - The standard used in judging spacings (or creepage and clearance distances) is indicated by the Standard No.

External protection (EP) - Tests on the component were conducted with the primary protected by external overcurrent protection.

EP Categories	Code
Specified current rating, branch protection	@B
Specified current rating, time delay fuse	@T
Specified current rating, not branch protection	@
Note: (@) - Indicates current rating of protection in amps.	

Field Connections (FC) - Code indicates whether supply and output connections have been investigated for field connections.

FC Categories	Code
Supply & output not investigated for FC	0
Supply not investigated for FC	1
Output not investigated for FC	2
Supply suitable for FC (+)	3
Output suitable for FC (+)	4
Supply & output suitable for FC (+)	5
Supply suitable for FC (++)	6
Output suitable for FC (++)	7
Supply & output suitable for FC (++)	8
(+) - Employs pressure wire terminals or terminal block suitable for field wiring.	
(++) - Employs a connector, or a cord terminating in a connector.	

Grounding Connection (GC) - Units with functional grounding connections (no safety grounding connection) shall

have dead metal parts bonded to the end product grounding means.

GC Categories	Code
Only functional grounding provided	0
Provided with safety grounding connection	1
Double insulated product	2

2) A test shall be conducted to determine whether a hazard is present when connected to an incorrect supply source if the user has access to voltage selection means employed in multiple rated supply voltage units.

This page and all contents are Copyright © 2004 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2004 Underwriters Laboratories Inc.®"

Online Certifications Directory - Notice of Disclaimer

By accessing these Listings, Designs, Constructions, Systems, and Assemblies, the user acknowledges and accepts the terms and conditions upon which this service is made available.

THIS INFORMATION AND ALL RELATED MATERIALS, SUPPORT, AND SERVICES ARE MADE AVAILABLE BY UL FOR USE ONLY BY USERS FOR THEIR INTERNAL PURPOSES AND IS "AS IS," WITHOUT ANY REPRESENTATION OR WARRANTY OF ANY KIND, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO ANY IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE.

UL cannot and does not warrant that this information is current, accurate, or complete. This database contains the names of companies who have qualified to use the UL Mark and those products for which samples have been evaluated by UL and judged to be eligible for Listing. The manufacturer is not obligated to label all of his production. Accordingly, the appearance of a company's name or product in this database does not in itself assure those products are covered under UL's Listing and Follow-Up Service. Only those products bearing the appropriate UL Mark should be considered covered under UL's Listing and Follow-Up Service. Any reproduction or re-transmission of this information is prohibited unless reproduced or re-transmitted in its entirety, including this Notice of Disclaimer.

UL does not permit hyperlinking to this website without its express prior written consent and the execution of a *hyperlinking agreement*.