

Terminal Protection to IP20



Dims: to DIN 43880  
W. 44mm


- Designed to balance the operation between motors, compressors, generators, etc
- "Help" function (allows 2<sup>nd</sup> relay to energise if required)
- Microprocessor based
- Isolated power supply with wide auxiliary operating supply voltage - 100 – 230V AC/DC
- Accepts up to 2, Voltage-free, N.O. contacts (i.e. pressure switches, relay contacts)
- Indicates error if inputs are applied in alternative sequence
- 2 x SPNO relay outputs 5A
- Green LED indication for supply status
- Individual Red LED indication for relay status
- Compact 44mm DIN Rail housing
- Other logic/switching patterns available on request<sup>2</sup>
- Can replace existing M3FFR



ISO 9001:2015  
Cert. No. 14125771

<sup>1</sup> Also known as "Load Sharing Relay", "Alternating Relay" or "Flip Flop Relay"

### FUNCTION DIAGRAM<sup>2</sup>



### TECHNICAL SPECIFICATION

Aux. Supply voltage Us (6, 7):	100 – 230V AC/DC
Frequency range:	48 – 63Hz (AC supplies)
Supply variation:	85 – 115% of Us
Power consumption (max.):	3VA
Pollution degree:	2
Overvoltage category:	III (IEC 60664)
Rated impulse withstand voltage:	4kV (1.2/50µs) IEC 60664
No. of Monitored inputs (1, 2, 5):	2
Max. cable length:	50m (relay to external contacts)
Typical response times:	
To relay energising	< 1s
To relay de-energising	< 1s
Time delay (t <sub>d</sub> ):	1s
Reset time:	380ms max.
Repeat accuracy:	0.5% @ constant conditions
Power on indication:	Green LED
Relay status indication:	Red LED x2
Ambient temperature:	-20 to +60°C
Relative humidity:	+95% max.
RLY1 (8, 9):	SPNO relay
RLY2 (10, 11):	SPNO relay
Output rating (all relays):	AC1 250V 5A (1250VA) AC15 250V 2A DC1 30V 3A (90W)
Electrical life:	≥ 150,000 ops at rated load
Dielectric voltage:	2kV AC (rms) IEC 60947-1
Rated impulse withstand voltage:	4kV (1.2/50µs) IEC 60664
Housing:	Grey flame retardant Lexan UL94 V0
Weight:	120g
Mounting option:	On to 35mm symmetric DIN rail to BS EN 60715
Terminal conductor size:	≤ 2 x 2.5mm <sup>2</sup> solid or stranded
Approvals:	Conforms to IEC, CE,  and RoHS Compliant. EMC: Immunity: EN 61000-6-2 Emissions: EN 61000-6-3

### INSTALLATION AND OPERATION



Installation work must be carried out by qualified personnel.

- BEFORE INSTALLATION, ISOLATE THE SUPPLY.
- Connect the unit as shown in the diagram below and ensure the voltage of the supply to be connected to terminals "6" and "7" is within the voltage rating of this product.
- Connect the external contact for "Input 1" across terminals "1" and "5" and the contact for "Input 2" across terminals "2" and "5".
- The connections to the Output Relays (shown as "RLY1" and "RLY2") should be wired according to the external load they are controlling/switching.
- Note that the LED's correspond to the Relay Outputs as follows: "Output 1" LED = "RLY1" status and "Output 2" LED = "RLY2" status.

#### Applying power.

- Apply power and the green "Power supply" LED will illuminate.
- If the external contacts are open both the red "Output 1"/"Output 2" LED's will remain extinguished.

#### Operating the unit (with power applied).

- Close the external contact connected to "Input 1" and "RLY1" relay will energise and corresponding red LED 1 illuminate. Open the contact and "RLY1" will de-energise and red LED extinguish.
- Close the same contact again and now "RLY2" relay will energise and corresponding red LED 2 illuminate. Open the contact and "RLY2" will de-energise and red LED extinguish.
- Next time "Input 1" contact is closed, "RLY1" will re-energise and the alternating sequence between the relays will continue.

#### "Help" function/feature


- With one of the external contacts already closed and output relay energised, closing the second external contact will energise the other relay. This allows both loads to run simultaneously if required. Additionally, if two inputs close simultaneously, there is a 1 second delay (t<sub>d</sub>) in between the other relay energising.

#### Troubleshooting

If the unit fails to operate correctly or as described, check the wiring is correct, supply voltage is present and within the operating limits specified. Please also see additional note in the Technical Specification column on the right.


Numbers shown above in bold/within brackets refer to terminal numbers on housing.

### CONNECTION DIAGRAM



### FRONT LED INDICATION

1. Output 1 status (Red) LED
2. Output 2 status (Red) LED
3. Power supply status (Green) LED



There are no user adjustments on this product

### DIMENSIONS

