



Certificate of Compliance

Certificate Number: LR 16186-36

Revision: LR 16186-57

Date Issued: January 27, 1997

Issued To: E-T-A CIRCUIT BREAKERS LTD.
236 Hood Rd.
Markham, ON L3R 3K8
Attention: Mr. Tony Bright

The products listed below are eligible to bear the CSA Mark.

Issued By: S. Jeffery, C.E.T.
Toronto, ON Canada

Signature

CLASS

3215 01 - SUPPLEMENTARY PROTECTORS

PRODUCTS

Appliance component protectors, magnetic trip, series trip, shunt trip or relay trip manual reset, with manual switching feature, with or without auxiliary contacts, Series 8340, (F, G and T), 1-, 2-, 3- and 4-pole, 30 A and less, 250 V ac and less, 50/60 Hz, 65 V dc and less.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 235-M89 - Supplementary Protectors