



JDYX2.E90660

Fuses, Miscellaneous, Miniature, and Micro - Component

Fuses, Miscellaneous, Miniature, and Micro - Component

Guide Information

FERRAZ SHAWMUT S A

E90660

1 RUE JEAN NOVEL

69626 VILLEURBANNE, FRANCE

For use with fuse holder:Micro, Types MBQ, MQ, 0.05-15 amp, 125 v, ac/dc.

Micro, Types MBS, MS, 0.05-7 amp, 125 v, ac/dc.

Micro, Type MRT, 0.080-6.3 amp, 250 vac.

Micro, Type SSQ, 0.1-7 amp, 125 vac.

Miniature, Types GSA, GSAP, 10-15 amp, 250 vac.

Miniature, Type 3JQ, 0.1-7.0 amp, 350 vac.

Miniature, Type 3JS, 0.1-3.0 amp, 300 vac.

Miniature, Types 3SF, 3SFP, 0.315-10 amp, 250 vac.

Miniature, Types 5HF, 5HFP, 0.1-10 amp, 250 vac.

Miniature, Types 5HT, 5HTP, 0.25-10 amp, 250 vac.

Miniature, Types 5SF, 5SFP, 0.08-10 amp, 250 vac.


Miniature, Types 5ST, 5STP, 0.063-10 amp, 250 vac.

Miniature, Indicator Type M, 1-4 Amp, 125 or 250 vac.

Miniature (5x20), Type FA followed by 0.125-12.5 amp, 250V, ac.

Miniature (5x20), Type SC, 8A, 250V, ac.

Supplemental, Type FC or FCAL followed by 0.160 to 10, 0.160 to 10 amp, 250 vac.

Marking: Company name or trademarks ,  or , type designation and Recognized Component Mark.

This page and all contents are Copyright © 2002 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.



JDYX2.GuideInfo

Fuses, Miscellaneous, Miniature, and Micro - Component

[Fuses] Fuses, Miscellaneous, Miniature, and Micro - Component

The devices covered under this category are incomplete in certain constructional features or restricted in performance capabilities and are intended for use as components of complete equipment submitted for investigation rather than for direct separate installation in the field. THE FINAL ACCEPTANCE OF THE COMPONENT IS DEPENDENT UPON ITS INSTALLATION AND USE IN COMPLETE EQUIPMENT SUBMITTED TO UNDERWRITERS LABORATORIES INC.

Component fuses covered by this category are intended for additional protection of individual circuits, specific components or internal wiring of radio, television, x-ray equipment, power supplies for electronic data processing equipment or similar appliances.

This page and all contents are Copyright © 2002 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

Notice of Disclaimer

By accessing these Listings, Designs, Constructions, Systems and Assemblies, the user acknowledges and accepts the terms and conditions upon which this service is made available.

THIS INFORMATION AND ALL RELATED MATERIALS, SUPPORT AND SERVICES ARE MADE AVAILABLE BY UL FOR USE ONLY BY USERS FOR THEIR INTERNAL PURPOSES AND IS "AS IS," WITHOUT ANY REPRESENTATION OR WARRANTY OF ANY KIND, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO ANY IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE.

UL cannot and does not warrant that this information is current, accurate, or complete. Users must independently confirm the conformance of any product to the applicable standards or requirements with the manufacturer of that product. Any reproduction or re-transmission of this information is prohibited unless reproduced or re-transmitted in its entirety, including this Notice of Disclaimer.

UL does not permit hyperlinking to this website without its express prior written consent and the execution of a hyperlinking agreement.

Copyright © 2002 Underwriters Laboratories Inc.® All rights reserved.

