20VR1

SAFETY ORGANIZATION(S):

THIS FILTER HAS BEEN FORMALLY RECOGNIZED, CERTIFIED OR APPROVED BY THE LISTED AGENCY. THEREFORE, ALL TEST/REQUIREMENTS SPECIFIED IN THE LATEST REVISION OF THE FOLLOWING AGENCY STANDARDS HAVE BEEN MET.

UL RECOGNIZED CSA CERTIFIED VDE APPROVED

UL 1283 CSA 22.2, NO.0,0.4,8 VDE 565-3

OPERATING SPECIFICATIONS:

20 AMP, 120/250 VAC 16 AMP./40°C, 250 VAC LINE VOLTAGE/CURRENT:

LINE FREQUENCY: 50-60Hz

MAX. LEAKAGE CURRENT, EACH: LINE TO GROUND:

.5 mA AT 120V 60Hz .83 mA at 250V 50Hz

OPERATING AMBIENT TEMP. RANGE: -10°C TO +40°C @ RATED CURRENT, 1.

IN AN AMBIENT, To, HIGHER THAN 40°C, THE MAXIMUM OPERATING CURRENT, Io, 15 AS FOLLOWS:

 $l_0 = Ir - \sqrt{\frac{85 - T_0}{45}}$

RELIABILITY SPECIFICATIONS:

STORAGE TEMPERATURE. -40°C TO +85°C
HUMIDITY. 21 DAYS @ 40°C 95% RH
CURRENT OVERLOAD TEST. 6 TIMES RATED CURRENT FOR 8 SECONDS

TEST SPECIFICATIONS:

INDUCTANCE: .88 mH NOMINAL CAPACITANCE: (MEASURED @ 1 KHz, 0.25VAC MAX., 25°C±1°C) LINE TO GROUND: .011 µF ±20% LINE TO LINE: .303 µF ±20% DISCHARGE RESISTOR: 680Kn


LINE/GROUND AND LINE/LINE, 6000Mg (MIN) AT 100VDC INSULATION RESISTANCE, 20°C AND 50% RH

RECOMMENDED RECEIVING INSPECTION HIPOT:

LINES TO GROUND: LINE TO LINE: 2250 VDC FOR 1 MINUTE 1450 VDC FOR 1 MINUTE

FILTER APPROVAL:

THE BEST WAY TO SELECT AND QUALIFY A FILTER IS FOR YOUR ENGINEERING TO TEST THE UNIT IN YOUR EQUIPMENT.



(MINIMUM) 50₽ INSERTION LOSS FREQUENCY . 15 .з .5 2 5 10 20 30 MHz COMMON 65 11 33 50 65 65 65 62 60 ďΒ DIFF. 3 3 15 65 65 65 60 52 52 dB

UNLESS OTHERWISE SPECIFIED, TOLERANCE TO BE ±.025 MATERIAL & FINISH: AS SUPPLIED

This document is proprietary to CORCOM INC. and is not to be reproduced nor used for manufacturing purposes except on CORCOM'S prior written consent.

POWER LINE FILTER

DATE: 9-15-93 CATALOG NO. PRVD. TAM 20VR1

CAD NO. 20VR1.07

Mouser Electronics

Authorized Distributor

Click to View Pricing, Inventory, Delivery & Lifecycle Information:

 $\frac{\text{TE Connectivity}}{^{20\text{VR1}}}:$