



# Certificate of Compliance

Certificate Number: LR 22310-335

Revision:

Date Issued: April 2, 1996

P. O. No. ~~9507012~~

9507102

Issued To: Omron Electronics, Incorporated  
One East Commerce Drive  
Schaumburg, IL 60173  
U. S. A.  
Attention: Mr. Gilbert R. Guajardo

*The products listed below are eligible to bear the CSA Mark.*

*\*NOTE: The "NRTL/C" indicator may appear adjacent to the CSA Mark.*

Issued By: A. Zemanek, P. Eng.  
Toronto, ON Canada

Signature

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

CLASS 3211 87 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus - CERTIFIED TO U.S. STANDARDS

## PRODUCTS

Solid state timers, Type H3RN with suffixes, open type, max rating: input 12V dc, 24V dc or 24V ac, 50/60 Hz, output rating 3A, 250V ac resistive.

## APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No.	14-95	- Industrial Control Equipment
UL Std No.	508	- Industrial Control Equipment

\* The "NRTL/C" indicator adjacent to the CSA Mark signifies that the product has been evaluated to the applicable ANSI/UL and CSA Standards, for use in the U.S. and Canada. NRTL, i.e. Nationally Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.