Monitoring Technique

VARIMETER Phase Sequence Relay MK 9056N





Your Advantage

- Correct sense of rotation of motors
- Simple wiring

Features

- According to IEC/EN 60 255-1
- Detection of wrong phase sequence
- LED indication of rotation
- 2 changeover contacts
- Wire connection: also 2 x 1.5 mm² stranded ferruled, or
- 2 x 2.5 mm² solid DIN 46 228-1/-2/-3/-4
- As option with pluggable terminal blocks for easy exchange of devices
- with screw terminals
- or with cage clamp terminals
- Width 22.5 mm

Product Description


The MK 9056N detect wrong phase sequence in 3-phase systems. To monitor phase failure it is more suitable to use an Asymmetry relay e.g. MK 9040N.

Approvals and Markings





Function Diagram



Indicators

green LED: on, when corresponding output relay is

active

Technical Data

Input

Nominal voltage U_N: 3 AC 42 ... 60 V, 100 ... 127 V 3 AC 220 ... 240, 380 ... 500 V

0.9 ... 1.1 U_N Voltage range: Nominal frequency of U_N: 50 / 60 Hz Nominal consumption: approx. 2 W

Output

2 changeover contacts Contact: Operate / release delay: < 100 / 50 ms

Thermal current I_{th}: 5 A

Switching capacity

to AC 15

NO contact: 3 A / AC 230 V IEC/EN 60 947-5-1 NC contact: 1 A / AC 230 V IEC/EN 60 947-5-1

to DC 13 1 A / DC 24 V NO contact: IEC/EN 60 947-5-1 NC contact: 1 A / DC 24 V IEC/EN 60 947-5-1

Electrical life

to AC 15 at 3 A, AC 230 V: Short circuit strength

5 x 105 switch. cycles IEC/EN 60 947-5-1

max. fuse rating:

IEC/EN 60 947-5-1 4 A gL

Mechanical life: > 20 x 10⁶ switching cycles

General Data

Operating mode: Temperature range: Continuous operation

Operation: - 20 ... + 60°C Storage: - 20 ... + 60°C Altitude: < 2.000 m


Clearance and creepage

distances

rated impulse voltage /

4 kV / 2 IEC 60 664-1 pollution degree:

Circuit Diagram



Connection Terminals

Terminal designation	Signal designation
11 1 1 2 1 3	Connection of the monitoring 3-phase system
	"incorrect phase sequence-signa- ling relais (2 changeover contacts)"

Technical Data

EMC

Electrostatic discharge: 8 kV (air) IEC/EN 61 000-4-2

HF irradiation

80 MHz ... 2.7 GHz: 10 V / m IEC/EN 61 000-4-3 Fast transients: 2 kV IEC/EN 61 000-4-4

Surge voltages

between

wires for power supply: 2 kV IEC/EN 61 000-4-5 between wire and ground: 4 kV IEC/EN 61 000-4-5 HF wire guided: 10 V IEC/EN 61 000-4-6 Interference suppression: Limit value class B EN 55 011

Degree of protection

Housing: IP 40 IEC/EN 60 529 Terminals: IP 20 IEC/EN 60 529 Thermoplastic with V0 behaviour Housing:

according to UL subject 94

Vibration resistance: Amplitude 0.35 mm,

frequency 10 ... 55 Hz, IEC/EN 60 068-2-6 Climate resistance: 20 / 060 / 04 IEC/EN 60 068-1

Terminal designation: EN 50 005 Wire connection DIN 46 228-1/-2/-3/-4

Screw terminals

(integrated): 1 x 4 mm² solid or

1 x 2.5 mm² stranded ferruled or 2 x 1.5 mm² stranded ferruled or

2 x 2.5 mm² solid

Insulation of wires or sleeve length:

8 mm Plug in with screw terminals

max. cross section

1 x 2.5 mm² solid or for connection:

1 x 2.5 mm² stranded ferruled Insulation of wires

or sleeve length: 8 mm

Plug in with cage clamp terminals max. cross section

1 x 4 mm² solid or for connection:

1 x 2.5 mm² stranded ferruled

min. cross section

for connection: 0.5 mm²

Insulation of wires

12 ±0.5 mm or sleeve length:

Wire fixing: Plus-minus terminal screws M 3.5 box terminals with wire protection or

cage clamp terminals

0.8 Nm Fixing torque: DIN rail

Mounting: IEC/EN 60 715

Weight: approx. 140 g

Dimensions

Width x height x depth:

MK 9056N: 22.5 x 90 x 97 mm MK 9056N PC: 22.5 x 111 x 97 mm MK 9056N PS: 22.5 x 104 x 97 mm

CCC-Data

Auxiliary voltage U,: 3 AC 42-60 V, 3 AC 100-127V,

3 AC 220-240 V

Switching capacity

to AC 15 NO contact:

1,5 A / AC 230 V IEC/EN 60 947-5-1




Technical data that is not stated in the CCC-Data, can be found in the technical data section.

Standard Types

MK 9056N.12 AC 380 ... 500 V 50 / 60 Hz Article number: 0054183

Output: 2 changeover contacts Nominal voltage U_N: AC 380 ... 500 V Width: 22.5 mm

Ordering Ecample



Options with Pluggable Terminal Blocks





Screw terminal (PS/plugin screw)

Cage clamp (PC/plugin cage clamp)

Removing the terminal blocks with cage clamp terminals

- 1. The unit has to be disconnected.
- Insert a screwdriver in the side recess of the front plate.
- 3. Turn the screwdriver to the right and left.
- Please note that the terminal blocks have to be mounted on the belonging plug in terminations.

