

# Certificate of Compliance

**Certificate:** 1505030 (LR 018677)

**Master Contract:** 154112

**Project:** 1505030

**Date Issued:** December 15, 2003

**Issued to:** **Wago Kontakttechnik GmbH**  
Hansastrasse 27  
Postfach 2880  
32423 Minden/Westf.  
GERMANY

*The products listed below are eligible to bear the CSA Mark shown*



**Authorized by:** G. Foulem

## PRODUCTS

CLASS 6228 01 - WIRE CONNECTING DEVICES - Terminal Assemblies

Terminal Block Assemblies, spring force type 2, 3, 4 and 5 poles configuration for stranded and solid insulated copper conductors

Type	Volt	Group	Wire-Range	A	Remarks
862-...2	600	D	20-12 AWG	5	2 poles
862-...2	300	C	20-12 AWG	20	2 poles
862-...3	600	D	20-12 AWG	5	3 poles
862-...3	300	C	20-12 AWG	20	3 poles
862-...4	600	D	20-12 AWG	5	4 poles
862-...4	300	C	20-12 AWG	20	4 poles
862-...5	600	D	20-12 AWG	5	5 poles
862-...5	300	C	20-12 AWG	20	5 poles

## Notes:

1. Certified for use in other equipment where the acceptability of the combination is to be determined by CSA International.

**Certificate:** 1505030

**Master Contract:** 154112

**Project:** 1505030

**Date:** December 15, 2003

---

2. The type designation is completed with suffixes indicating colour of body, number of conductors, mechanical details.

**APPLICABLE REQUIREMENTS**

- |                                 |   |  |
|---------------------------------|---|--|
| CSA Standard C22.2 No. 0-M91    | - | General Requirements Canadian Electrical Code, Part II |
| CSA Standard C22.2 No. 158-1987 | - | Terminal Blocks  |

Electrical Certification Notice No. 584B.



## *Supplement to Certificate of Compliance*

**Certificate:** 1505030 (LR018677)

**Master Contract:** 154112

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
1505030	December 15, 2003	CSA original certification on Terminal Blocks Type 862-...